



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

01/06/2022

Permit # 000042578

L-28215

Lipscomb & Eagle

Re: Lot 24 Emerald Cove, Phase 2

To Whom It May Concern:

The top of the finished slab on said parcel is 154.34 feet. The required finished floor elevation is 152 feet per the building permit. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757