CAROL CHADWICK, P.E.

Civil Engineer
1208 S.W. Fairfax Glen
Lake City, FL 32025
307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

June 24, 2024

DeErra Yates 386.697.4698 Deerra22@hotmail.com

re: ELEVATION LETTER - 2183 SE OCTOBER ROAD, LAKE CITY, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. Per the flood report by SRWMD, there are wetlands or floodplains on the east half of the site; however, the home will constructed in zone X. Refer to the attached site plan by others.

The topography of the site drains to the southwest. The finished floor elevation of the home shall be I2" above the adjacent ground for the entire perimeter of the foundation, except driveways and sidewalks which must be flush with the finished floor elevation. The finished floor of the home will be below required elevation of one foot above the adjacent road.

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,

A SEGO A

Digitally signed by Carol Chadwick DN: c=US, o=Florida, dnQualifier=A01410D0000018D463 84E7500032FEE, cn=Carol Chadwick Date: 2024.06.24 09:14:31 -04'00'

Carol Chadwick, P.E.

attachments: SRWMD Flood Report \$ site plan sketch

This item has been digitally signed and sealed by Carol Chadwick, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies. CC Job #FL24338

# **EFFECTIVE FLOOD INFORMATION REPORT**



### **Location Information**

County: COLUMBIA

Parcel: 126S1709651001

Flood Zone: A, X

Flood Risk: HIGH

1% Annual Chance Base Flood Elev\* Not

**Applicable** 

10% Annual Chance Flood Elev\* Not Applicable

50% Annual Chance Flood Elev\* Not Applicable

\* Flood Elevations shown on this report are in NAVD 88 and are derived from FEMA flood mapping products, rounded to the nearest tenth of a foot. For more information, please see the note below

## **Legend with Flood Zone Designations**

1% Flood -Floodway (High Area Not Included CrossSections Wetlands County Boundaries 1% Flood - Zone AE (High SFHA Decrease Risk) 1% Flood - Zone A SFHA Increase FIRM Panel Index (HighRisk) Depressions Parcels 1% Flood - Zone VE (HighRisk) 0.2% Flood-Shaded Zone X BaseFlood Elevations (BFE) River Marks (Moderate Risk) **Supplemental Information** Map Effective Date Watershed Santa Fe 2/4/2009 Special Flood Hazard Yes Area

Anywhere it can rain, it can flood Know your risk.



www.srwmdfloodreport.com

FIRM Panel(s) 12023C0505C

The information herein represents the best available data as of the effective map date shown. The Federal Emergency Management Agency (FEMA) Flood Map Service Center (https://msc.fema.gov) maintains the database of Flood Insurance Studies and Digital Flood Insurance Rate Maps, as well as additional information such as how the Base Flood Elevations (BFEs) and/or floodways have been determined and previously issued Letters of Map Change. Requests to revise flood information may be provided to the District during the community review period on preliminary maps, or through the appropriate process with FEMA <a href="Change Your Flood Zone Designation">Change Your Flood Zone Designation</a> | FEMA.gov. Information about flood insurance may be obtained at (https://www.floodsmart.com)

## **Base Flood Elevation (BFE)**

The elevation shown on the Flood Insurance Rate Map for Zones AE, AH, A1-A30, AR, AO, V1-V30, and VE that indicates the water surface elevation resulting from a flood that has a one percent chance of equaling or exceeding that level in any given year.

#### Α

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. Because detailed analyses are not performed for such areas; no depths or base flood elevations are shown within these zones.

## AE. A1-A30

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. In most instances, base flood elevations derived from detailed analyses are shown at selected intervals within these zones.

## AΗ

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. Usually areas of ponding with flood depths of 1 to 3 feet. Base Flood Elevations are determined.

#### AO

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. Usually areas of sheet flow on sloping terrain with flood depths of 1 to 3 feet.Base Flood Elevations are determined.

## **Supplemental Information:**

10%-chance flood elevations (10-year flood-risk elevations) and 50%-chance flood elevations (2-year flood-risk elevations), are calculated during detailed flooding studies but are not shown on FEMA Digital Flood Insurance Rate Maps (FIRMs). They have been provided as supplemental information in the Flood Information section of this report.

## **AE FW (FLOODWAYS)**

The channel of a river or other watercourse and the adjacent land areas that must be reserved in order to discharge the base flood (1% annual chance flood event). The floodway must be kept open so that flood water can proceed downstream and not be obstructed or diverted onto other properties.

Please note, if you develop within the regulatory floodway, you will need to contact your Local Government and the Suwannee River Water Management District prior to commencing with the activity. Please contact the District at 800.226.1066.

## VE

Areas with a 1% annual chance of flooding over the life of a 30-year mortgage with additional hazards due to storm-induced velocity wave action. Base Flood Elevations (BFEs) derived from detailed analyses.

## X 0.2 PCT (X Shaded, 0.2 PCT ANNUAL CHANCE FLOOD HAZARD)

Same as Zone X; however, detailed studies have been performed, and the area has been determined to be within the 0.2 percent annual chance floodplain (also known as the 500-year flood zone). Insurance purchase is not required in this zone but is available at a reduced rate and is recommended.

## X

All areas outside the 1-percent annual chance floodplain are Zone X. This includes areas of 1% annual chance sheet flow flooding where average depths are less than 1 foot, areas of 1% annual chance stream flooding where the contributing drainage area is less than 1 square mile, or areas protected from the 1% annual chance flood by levees. No Base Flood Elevations or depths are shown within this zone. Insurance purchase is not required in these zones.

## LINKS FEMA:

http://www.fema.gov

#### SRWMD:

http://www.srwmd.state.fl.us

## CONTACT SRWMD 9225 County Road 49 Live Oak, FL 32060

(386) 362-1001

Toll Free: (800) 226-1066



# Columbia County Property Appraiser Jeff Hampton | Lake City, Florida | 386-758-1083

**PARCEL: 12-6S-17-09651-001 (44012)** | NON AG ACREAGE (9900) | 15.3 AC THE FOLLOWING DESC LYING IN SEC 12: BEG NW COR OF SW1/4 OF SW1/4, E 1319.94 FT TO NE COR OF SV

THE FOLLOWING DESC LYING IN SEC 12: BEG NW COR OF SW1/4 OF SW1/4, E 1319.94 FT TO NE COR OF SW1/4 OF SW1/4, S 493.80 FT, W 1545.61 FT TO E ACCESS R/W

	YATES LARRY BRANDON			2024 Working Values			
Owner	FORT WHITE, FL 32038		Mkt Lnd	\$45,900	Appraised	\$45,900	
"""			Ag Lnd	\$0	Assessed	\$45,900	
l				Bldg	\$0	Exempt	\$0
Site:	2183 SE OCTOBER, LAKE			XFOB	\$0		county:\$45,900
	CITY			Just	\$45,900	Total	city:\$0
Sales Info	11/9/2021 11/5/2021		/ (U) / (U)			Taxable	other:\$0 school:\$45,900

NOTES: Columbia County, FL

The information presented on this website was derived from data which was compiled by the Columbia County Property Appraiser Office solely for the governmental purpose of property assessment. This information should not be relied upon by anyone as a determination of the ownership of property or market value. No warranties, expressed or implied, are provided for the accuracy of the data herein, it's use, or it's interpretation. This website was last updated: 5/16/2024 and may not reflect the data currently on file at our office.

GrizzlyLogic.com