

INSPECTION DAILY REPORT

No.: _____

0215.1900017.000

PAGE: _____ OF _____

PROJECT No.: Lot 43 - Rolling Meadows
 PROJECT NAME: Sparks Construction
 PROJECT LOCATION: 2799W Buttercup Dr.
Lake city FL
 CLIENT: Sparks Construction
 PERMIT AGENCY: Columbia County
 PERMIT No.: 78972

DATE: 12.18.2019
 TIME ON SITE: _____
 TRAVEL TIME: _____
 WEATHER: Sunny
 TEMPERATURE: 55°
 UES INSPECTOR: M. McElroy BN 6543

APPLICABLE PERSONNEL ON SITE / COMPANY:
BARES Plumbing Inc.

APPLICABLE PLANS USED FOR INSPECTION:

Approved Plan Set:

ELEMENTS INSPECTED: 1ST Rough Plumbing (underground), 1ST Rough Electric (underground)

FIELD OBSERVATIONS (NUMBER EACH ITEM):

1.) Underground Rough Plumbing - Approved
- DWV only on 1ST Rough - All supply lines
to be inspected AT 2ND Rough.

2.) Underground Rough Electric - Approved.



THE ABOVE REFERENCED CONSTRUCTION WAS NOTED IN PLACE IN SUBSTANTIAL CONFORMANCE TO THE PLANS AND SPECIFICATIONS, EXCEPT AS NOTED HEREIN.

Universal Engineering Sciences, Inc.
 4475 SW 35th Terrace Gainesville, FL 32608
 (352) 372-3392
 Fax (352) 336-7914

