

May 1, 2013

Trademark Construction
Lake City, FL 32025

OK
B2K
7 May 2013
✓

Subject: Lot 20, Forest Country, 6th Addition Elevation Letter

Dear Matt:

Daniel & Gore, LLC has performed a vertical survey on Lot 20, Forest Country, 6th Addition, Columbia County, Florida from a benchmark being a 60d nail in an oak tree in the North right of way of SW Pinehurst Drive at Lot 9 (elevation – 89.15', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation of Lot 20 to be 110.4'.
- The top of the form board of the foundation is at 111.0', being the 0.6' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM





Crews Engineering Services, LLC

Columbia County Building Department
135 NE Hernando Ave.
Lake City, FL 32055

RE:

McDuffie Residence
Permit # 30942

I will permit the Contractor of the above project to adjust the construction of the continuous footing in the manner below:

1. The Contractor may remove the transverse reinforcement shown on page A-3 of the plans.

This letter does not permit any other changes to the construction of the project. All longitudinal reinforcement shall remain. Any additional structural changes must be approved by the Engineer.

Brett A. Crews P.E. 65592

A handwritten signature in black ink, enclosed within a dashed circular line. Below the signature, the date "4-22-2017" is written.

Certificate of Authorization
NO. 28022