

DATE 09/20/2006

Columbia County Building Permit

PERMIT

This Permit Expires One Year From the Date of Issue

000024992

APPLICANT WENDY GRENNELL PHONE 288-2428
ADDRESS 3104 SW OLD WIRE ROAD FT. WHITE FL 32038
OWNER SHERIE VICKERS PHONE 454-5140
ADDRESS 762 SW BARNEY ST HIGH SPRINGS FL 32643
CONTRACTOR CHESTER KNOWLES PHONE 755-6441
LOCATION OF PROPERTY 441S, TR ON BARNEY ST., PROPERTY ON LEFT (762)

TYPE DEVELOPMENT MH,UTILITY ESTIMATED COST OF CONSTRUCTION 0.00
HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES
FOUNDATION WALLS ROOF PITCH FLOOR
LAND USE & ZONING A-3 MAX. HEIGHT
Minimum Set Back Requirments: STREET-FRONT 30.00 REAR 25.00 SIDE 25.00
NO. EX.D.U. 0 FLOOD ZONE X DEVELOPMENT PERMIT NO.

PARCEL ID 09-7S-17-09961-004 SUBDIVISION
LOT BLOCK PHASE UNIT 0 TOTAL ACRES

IH0000509
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor
EXISTING 06-0822-N BK JH Y
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: ONE FOOT ABOVE THE ROAD

Check # or Cash 564

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic
date/app. by date/app. by date/app. by
Under slab rough-in plumbing Slab Sheathing/Nailing
date/app. by date/app. by date/app. by
Framing Rough-in plumbing above slab and below wood floor
date/app. by date/app. by
Electrical rough-in Heat & Air Duct Peri. beam (Lintel)
date/app. by date/app. by date/app. by
Permanent power C.O. Final Culvert
date/app. by date/app. by date/app. by
M/H tie downs, blocking, electricity and plumbing Pool
date/app. by date/app. by
Reconnection Pump pole Utility Pole
date/app. by date/app. by date/app. by
M/H Pole Travel Trailer Re-roof
date/app. by date/app. by date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00
MISC. FEES \$ 200.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 0.00 WASTE FEE \$
FLOOD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 275.00
INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

This Permit Must Be Prominently Posted on Premises During Construction

PLEASE NOTIFY THE COLUMBIA COUNTY BUILDING DEPARTMENT AT LEAST 24 HOURS IN ADVANCE OF EACH INSPECTION, IN ORDER THAT IT MAY BE MADE WITHOUT DELAY OR INCONVIENCE, PHONE 758-1008. THIS PERMIT IS NOT VALID UNLESS THE WORK AUTHORIZED BY IT IS COMMENCED WITHIN 6 MONTHS AFTER ISSUANCE.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

9/21

For Office Use Only

(Revised 6-23-05)

Zoning Official

Building Official

AP# 0609-44

Date Received 9-18-06

By

Permit #

24992

Flood Zone

Development Permit

N/A

Zoning

A-3

Land Use Plan Map Category

A-3

Comments

FEMA Map#

Elevation

Finished Floor

River

In Floodway

☒ Site Plan with Setbacks Shown

☒ EH Signed Site Plan

☐ EH Release

☒ Well letter

☐ Existing well

☒ Copy of Recorded Deed or Affidavit from land owner

☒ Letter of Authorization from Installer

- Property ID # 09-25-17-09961-004 Must have a copy of the property deed
- New Mobile Home ☒ Used Mobile Home _____ Year 07
- Applicant Wendy Grennell Phone # 386-288-2428
- Address 3104 SW Old Wire Rd Ft White FL 32038
- Name of Property Owner Sherie Vickers Phone# 386-454-5140
- 911 Address 762 SW Barney St. High Springs FL
- Circle the correct power company - FL Power & Light - Clay Electric 32643
(Circle One) - Suwannee Valley Electric - Progress Energy
- Name of Owner of Mobile Home Sherie Vickers Phone # 386-454-5140
- Address PO Box 986 High Springs FL 32643
- Relationship to Property Owner Same
- Current Number of Dwellings on Property 0
- Lot Size 1289' x 392' x 496' x 791' x 524' Total Acreage 14.029
- Do you : Have an Existing Drive or need a Culvert Permit or a Culvert Waiver (Circle one)
- Is this Mobile Home Replacing an Existing Mobile Home No (PD)
- Driving Directions to the Property Hwy 441 South past I-75
(R) on SW Barney Street, property on
(L) 762
- Name of Licensed Dealer/Installer Jessick Cluster Knowles Phone # 755-6441
- Installers Address 5801 SW SR 47 Lake City FL 32024
- License Number JH0000509 Installation Decal # 274128

PERMIT NUMBER

Installer Jessie A. "Chester" Knowles License # IH 000509



Address of home being installed 762 SW Barry St.

Manufacturer Fleetwood Length x width 28 X 48

NOTE: If home is a single wide fill out one half of the blocking plan
If home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used) where the sidewall ties exceed 5 ft 4 in.

Installer's initials JLK



New Home ☒ Used Home ☐
Home installed to the Manufacturer's Installation Manual ☒
Home is installed in accordance with Rule 15-C. ☐
Single wide ☐ Wind Zone II ☒ Wind Zone III ☐
Double wide ☒ Installation Decal # 294128
Triple/Quad ☐ Serial # 9854 A+B

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16" x 16" (256)	18 1/2" x 18 1/2" (342)	20" x 20" (400)	22" x 22" (484)*	24" x 24" (576)*	26" x 26" (676)
1000 psf	3'	4'	4'	5'	6'	7'	8'
1500 psf	4'	6'	6'	7'	8'	8'	8'
2000 psf	6'	8'	8'	8'	8'	8'	8'
2500 psf	7'	8'	8'	8'	8'	8'	8'
3000 psf	8'	8'	8'	8'	8'	8'	8'
3500 psf	8'	8'	8'	8'	8'	8'	8'

* Interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 23 1/2 x 31 1/2

Perimeter pier pad size N/A

Other pier pad sizes (required by the mfg.) 16 X 16

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening 10'

Pier pad size 23 1/2 x 31 1/2

4 ft ☒ 5 ft

FRAME TIES

within 2' of end of home spaced at 5' 4" oc ☒

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)

Manufacturer

Longitudinal Stabilizing Device w/ Lateral Arms

Manufacturer

OTHER TIES

Number

Sidewall 16

Longitudinal 16

Marriage wall min. 2

Shearwall min. 2

POPULAR PAD SIZES

Pad Size	Sq in
16 x 16	256
16 x 18	288
18.5 x 18.5	342
16 x 22.5	360
17 x 22	374
13 1/4 x 26 1/4	348
20 x 20	400
17 3/16 x 25 3/16	441
17 1/2 x 25 1/2	446
24 x 24	576
26 x 26	676

ANCHORS

PERMIT WORKSHEET

page 2 of 2

PERMIT NUMBER

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to _____ psf or check here to declare 1000 lb. soil ☒ without testing.

x 1.0 x 1.0 x 1.0

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 8 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

Assumed

x 1.0 x 1.0 x 1.0

TORQUE PROBE TEST

The results of the torque probe test is 1101 V system inch pounds or check here if you are declaring 5' anchors without testing USING. A test showing 275 inch pounds or less will require 4 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. I understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may requires anchors with 4000 lb. holding capacity.

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name

Date Tested

David Chute
8-31-06

Installer's Initials

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg. 15C-1

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg. 15C-1

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg. 15C-1

Site Preparation

Debris and organic material removed ☒ Swale ☐ Pad ☐ Other ☐

Fastening multi wide units

Floor: Type Fastener: lags Length: 6" Spacing: 20"
Walls: Type Fastener: SCWS Length: 4" Spacing: 24"
Roof: Type Fastener: STAPS Length: 1 1/2" Spacing: 48"
For used homes a min. 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherproofing requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's Initials

J.C.K.

Type gasket Roll Foam
Pg. Electric Installed

Installed:

Between Floors Yes ☒
Between Walls Yes ☒
Bottom of ridgebeam Yes ☒

Weatherproofing

The bottomboard will be repaired and/or taped. Yes ☒ Pg. 15C-1
Siding on units is installed to manufacturer's specifications. Yes ☒
Fireplace chimney installed so as not to allow intrusion of rain water. Yes ☒

Miscellaneous

Skirting to be installed. Yes ☒ No ☐
Dryer vent installed outside of skirting. Yes ☒ N/A ☐
Range downflow vent installed outside of skirting. Yes ☒ N/A ☐
Drain lines supported at 4 foot intervals. Yes ☒
Electrical crossovers protected. Yes ☒
Other: 15C-1 MAY OR MAY NOT HAVE PAGE #

IN SETUP MANUAL

Installer verifies all information given with this permit worksheet is accurate and true based on the manufacturer's installation instructions and or Rule 15C-1 &

Installer Signature *David Chute* Date 8-31

HALL'S PUMP & WELL SERVICE, INC.

SPECIALIZING IN 4"-6" WELLS



DONALD AND MARY HALL
OWNERS

PHONE (904) 752-1854
FAX (904) 755-7022
~~XXXX NORTH WYCK STREET~~
LAKE CITY, FLORIDA 32055
904 NW Main Blvd.


June 12, 2002

NOTICE TO ALL CONTRACTORS


Please be advised that due to the new building codes we will use a large capacity diaphragm tank on all new wells. This will insure a minimum of one (1) minute draw down or one (1) minute refill. If a smaller diaphragm tank is used then we will install a cycle stop valve which will produce the same results.

If you have any questions please feel free to call our office anytime.


Thank you,


Donald D. Hall
DDH/jk

SITE PLAN EXAMPLE / WORKSHEET



Use this example to draw your own site plan. Show all existing buildings and any other homes on this property and show the distances between them. Also show where the roads or roads are around the property. This site plan can also be used for the 911 Addressing department if you include the distance from the driveway to the nearest property line.



Permit Me Services
3104 S W Old Wire Rd
Ft White, FL 32038
Wendy Grennell Owner
386-288-2428 Cell
386-466-1866 Office / Fax

MOBILE HOME INSTALLER LIMIT POWER OF ATTORNEY

I, Jessie L. "Chester" Knowles, license number IH 0000509 authorize Wendy Grennell or Tisa Therrell to be my representative and act on my behalf in all aspects of applying for a mobile home permit to be placed on the following described property. Property located in Columbia County, State of Florida.

Mobile Home Owner Name: Sherie Vickers

Property Owner Name: Sherie Vickers

911 Address: SW Barney St. City

Sec: 09 Twp: 75 Rge: 17 Tax Parcel # 09961-004

Signed: Jessie L Chester Knowles
Mobile Home Installer

Sworn to and described before me this 10 day of September 2006

Amanda L Grooms
Notary public

AMANDA L GROOMS Personally known ✓
Notary Name

DL ID



Permit Me Services
3104 S W Old Wire Rd
Ft White, Fl 32038
Wendy Grennell Owner
386-288-2428 Cell
386-466-1866 Office / Fax

CONSENT FOR MOBILE HOME PERMIT APPLICATIONS

I/We Sheri Vickers, authorize Wendy Grennell or Tisa Therrell to act on my/our behalf while applying for all necessary permits, and further authorize mobile home installer, Clister Knowles license number TH0000529 to place the mobile home described below, on the property described below in Columbia County, State of Florida.

Property Owner Name: Sheri Vickers

911 Address: SW Barney St. City

Sec: 09 Twp: 75 Rge: 17 Tax Parcel # 09961-004

Mobile Home Make: Fleetwood Year 07 Size 28 x 48 ft

Serial Number ordered

Signed
Owner (1) Sheri Vickers Owner (2)

Witness: Wendy Grennell Witness:

Sworn to and described before me this 13 day of September 2006

Amanda L Grooms

Notary public

AMANDA L GROOMS Known to me

Notary Name

DL



Best

RETURN TO

U. S. MAIL
600 N.E. Santa Fe Blvd.
High Springs, FL 32643
USH-2606

Inst:2004005695 Date:03/15/2004 Time:10:30

Doc Stamp-Deed : 451.50

B DC, P. DeWitt Cason, Columbia County B:1009 P:1786

[Space Above This Line for Recording Data]

Parcel I.D. No.: 09-7S-17-09-961-000

WARRANTY DEED

This Indenture made this **18th** day of **February, 2004** BETWEEN **EDWARD ZACK and REGINA ZACK, HUSBAND AND WIFE, GRANTOR***, whose post office address is 598 SW BARNEY STREET, HIGH SPRINGS, FL 32643 and **SHERIE L. VICKERS, A SINGLE PERSON, GRANTEE***, whose post office address is XXX BARNEY ROAD, HIGH SPRINGS, FL 32643.

WITNESSETH, That said Grantor, for and in consideration of the sum of TEN AND 00/100'S (\$10.00) Dollars and other good and valuable considerations to said grantor in hand paid by said grantee, the receipt whereof is hereby acknowledged, has granted, bargained and sold to the grantee and grantee's heirs forever the following described land located in the County of COLUMBIA, State of Florida, to-wit:

SEE ATTACHED EXHIBIT "A"

SUBJECT TO covenants, restrictions and easements of record, if any; however, this reference thereto shall not operate to reimpose same.

and the grantor hereby covenants with said grantee that the grantor is lawfully seized of said land in fee simple; that the grantor has good right and lawful authority to sell and convey said land; that the grantor hereby fully warrants the title to said land, and will defend the same against the lawful claims of all persons whomsoever; and that said land is free of all encumbrances, except taxes accruing subsequent to December 31, 2003.

*Singular and plural are interchangeable as context requires.

IN WITNESS WHEREOF, Grantor has hereunto set grantor's hand and seal this day and year first above written.

WITNESSES

Jannette S. Boyd
Typed Name: Jannette S. Boyd

Leslie Ketchel
Typed Name: Leslie Ketchel

COUNTY OF Alachua

Edward Zack
EDWARD ZACK

Regina M. Zack
REGINA ZACK

"EXHIBIT "A"
Legal Description

A PORTION OF NORTHEAST QUARTER OF THE NORTHWEST QUARTER OF SECTION 9, TOWNSHIP 7 SOUTH, RANGE 17 EAST, COLUMBIA COUNTY, FLORIDA; BEING MORE PARTICULARLY DESCRIBED AS FOLLOWS:

COMMENCE AT A FOUND CONCRETE MONUMENT AT THE NORTHEAST CORNER OF SAID NORTHEAST QUARTER OF THE NORTHWEST QUARTER OF SECTION 9, TOWNSHIP 7 SOUTH, RANGE 17 EAST, AND RUN THENCE SOUTH $01^{\circ}22'09''$ EAST 30.00 FEET TO A SET $5/8''$ REBAR ON THE SOUTH RIGHT OF WAY LINE OF SW BARNEY STREET (60 FOOT RIGHT OF WAY); THENCE SOUTH $88^{\circ}05'35''$ WEST, ALONG SAID RIGHT OF WAY LINE, 793.31 FEET TO A SET $5/8''$ REBAR AND THE POINT OF BEGINNING; THENCE SOUTH $01^{\circ}19'42''$ EAST, 1289.64 FEET TO A SET $5/8''$ REBAR; THENCE SOUTH $88^{\circ}12'00''$ WEST, 392.75 FEET TO A FOUND CONCRETE MONUMENT; THENCE NORTH $01^{\circ}21'43''$ WEST, 496.92 FEET TO A FOUND CONCRETE MONUMENT; THENCE SOUTH $88^{\circ}18'20''$ WEST, 131.92 FEET TO A FOUND CONCRETE MONUMENT; THENCE NORTH $01^{\circ}19'42''$ WEST, 791.50 FEET TO A FOUND CONCRETE MONUMENT ON THE AFOREMENTIONED SOUTH RIGHT OF WAY LINE OF SW BARNEY STREET; THENCE NORTH $88^{\circ}05'35''$ EAST, ALONG SAID SOUTH RIGHT OF WAY LINE, 524.98 FEET TO THE POINT OF BEGINNING.

CONTAINING 14.029 ACRES MORE OR LESS.



Columbia County Property Appraiser

DB Last Updated: 8/1/2006

Parcel: 09-7S-17-09961-004

2006 Proposed Values

Tax Record

Property Card

Interactive GIS Map

Print

Owner & Property Info

<< Prev

Search Result: 3 of 3

Owner's Name	VICKERS SHERIE L
Site Address	BARNEY
Mailing Address	P O BOX 986 HIGH SPRINGS, FL 32643
Description	COM AT NE COR OF NE1/4 OF NW1/4, RUN S 30 FT TO S R/W LINE OF BARNEY ST, THENCE W 793.31 FT TO POB, THENCE S 1289.64 FT, W 392.75 FT, N 496.92 FT, W 131.92 FT, N 791.50 FT, E 524.98 FT TO POB. ORB 486-692, 551-219, 739-439, WD 1009-1786

Use Desc. (code)	PASTURELAN (006200)
Neighborhood	9717.00
Tax District	3
UD Codes	MKTA02
Market Area	02
Total Land Area	14.029 ACRES

Property & Assessment Values

Mkt Land Value	cnt: (1)	\$1,250.00
Ag Land Value	cnt: (1)	\$2,525.00
Building Value	cnt: (0)	\$0.00
XFOB Value	cnt: (0)	\$0.00
Total Appraised Value		\$3,775.00

Just Value	\$85,424.00
Class Value	\$3,775.00
Assessed Value	\$3,775.00
Exempt Value	\$0.00
Total Taxable Value	\$3,775.00

Sales History

Sale Date	Book/Page	Inst. Type	Sale VImp	Sale Qual	Sale RCode	Sale Price
2/18/2004	1009/1786	WD	V	U	01	\$64,500.00

Building Characteristics

Bldg Item	Bldg Desc	Year Blt	Ext. Walls	Heated S.F.	Actual S.F.	Bldg Value
NONE						

Extra Features & Out Buildings

Code	Desc	Year Blt	Value	Units	Dims	Condition (% Good)
NONE						

Land Breakdown


Lnd Code	Desc	Units	Adjustments	Eff Rate	Lnd Value
006200	PASTURE 3 (AG)	14.029 AC	1.00/1.00/1.00/1.00	\$180.00	\$2,525.00
009910	MKT.VAL.AG (MKT)	14.029 AC	1.00/1.00/1.00/1.00	\$0.00	\$84,174.00
009946	WELL (MKT)	1.000 UT - (.000AC)	1.00/1.00/1.00/1.00	\$1,250.00	\$1,250.00

Columbia County Property Appraiser

DB Last Updated: 8/1/2006

<< Prev

3 of 3




Columbia County Property Appraiser

J. Doyle Crews, CFA - Lake City, Florida - 386-758-1083

PARCEL: 09-7S-17-09961-004 - PASTURELAN (006200)

Name: VICKERS SHERIE L	LandVal	\$1,250.00
Site: BARNEY	BldgVal	\$0.00
Mail: P O BOX 986	ApprVal	\$3,775.00
High Springs, FL 32643	JustVal	\$85,424.00
Sales Info: 2/18/2004 \$64,500.00 V / U	Assd	\$3,775.00
	Exmpt	\$0.00
	Taxable	\$3,775.00

0 0.08 0.16 0.24 mi



This information, GIS Map Updated: 8/1/2006, was derived from data which was compiled by the Columbia County Property Appraiser Office solely for the governmental purpose of property assessment. This information should not be relied upon by anyone as a determination of the ownership of property or market value. No warranties, expressed or implied, are provided for the accuracy of the data herein, it's use, or it's interpretation. Although it is periodically updated, this information may not reflect the data currently on file in the Property Appraiser's office. The assessed values are NOT certified values and therefore are subject to change before being finalized for ad valorem assessment purposes.


COM AT NE COR OF NE1/4 OF	VICKERS SHERIE L	09-7S-17-09961-004	Columbia County	200
NW1/4, RUN S 30 FT TO S R/W	P O BOX 986			CARD 0
LINE OF BARNEY ST, THENCE W	HIGH SPRINGS, FL 32643	PRINTED	8/01/2006 11:09	BY .
793.31 FT TO POB, THENCE		APPR	7/21/2005 DF	

TOTAL											GRANTEE								
EXTRA FEATURES						FIELD CK:													
AE BN	CODE	DESC	LEN	WID	HGHT	QTY QL	YR	ADJ	UNITS UT	PRICE	ADJ UT PR	SPCD %	%GOOD	X					
N	006200	PASTURE 3 A-1	0002					1.00	1.00	1.00	1.00	14.029 AC	180.000	180.00					
N	009910	MKT.VAL.AG A-1	0002					1.00	1.00	1.00	1.00	14.029 AC							
Y	009946	WELL	0002					1.00	1.00	1.00	1.00	1.000 UT	1250.000	1250.00					
2006																			

**Application for Onsite Sewage Disposal System
Construction Permit. Part II Site Plan**
Permit Application Number: 06-182211

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH UNIT

VICKERS/CR 06-3678



Site Plan Submitted By Paul D. [Signature] Date 9/18/06
Plan Approved ☒ Not Approved ☐ Date 9/18/06
By MM 02 Columbia CPHU

Notes: _____

COLUMBIA COUNTY
OFFICE
OF
ADMINISTRATION

M/H OCCUPANCY

COLUMBIA COUNTY, FLORIDA

Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 09-7S-17-09961-004

Building permit No. 000024992

Permit Holder CHESTER KNOWLES

Owner of Building SHERIE VICKERS

Location: 762 SW BARNEY ST, HIGH SPRINGS, FL 32643



Date: 10/27/2006

Randy Jones by faith
Building Inspector

POST IN A CONSPICUOUS PLACE
(Business Places Only)