



City of Lake City Accessibility Letter Required before Building Permit Issuance



Service Representatives :

Growth Management: growthmanagement@lcfla.com,

Utilities: PelhamS@lcfla.com, MedearisK@lcfla.com, McGhinB@lcfla.com

Date: 4/7/2025

County Application # 70262

Applicant Name: JENNIFER

Phone: (713) 570-3112

Email: JENNIFER.BUDET@CROWNCastle.COM

Site Address: 1705 W US HIGHWAY 90 LAKE CITY, FL 32055

Parcel: 36-3S-16-02590-001

Acres: 18.51

Project Description: Communications Tower

Existing Structures on Property:

Any tree removal:

Number of trees removed:

Trees remaining:

Utilities:

Utility Accessibility: Water: Available Sewer: Available Gas: Available City Letter of Accessibility Required: No

Utility Active: Water: Inactive Sewer: Inactive Gas: Inactive Has Impact Fee: No Impact Fees paid:

Customer service official's name: *Shasta Pelham*

Reviewed: 4/10/2025

Requires Tap Inspection: No

Customer service official's notes: If digging is required, locates must be obtained to ensure that the existing utility infrastructure is not damaged or obstructed.

Zoning:

Minimum Setback Requirements: Font: Side: Rear:

Landscape Requirements:

Flood Zone: B.F.E.: Finished Floor Elevation Requirement:

Site Approval Plan:

Special Exception: Variance:

Documents Required:

Needed Before Power: No Needed Before CO: No

Zoning official clearance Date Reviewed:

Access:

Permit Issued: Needed Before CO:

Access official clearance Date Reviewed:

Code Enforcement:

Code Enforcement Cases: None Case Notes:

Code Enforcement clearance Date Reviewed:

Special Notes to be noted on permit