




REFLECTED CEILING PLAN PLAN 1752F-25-01-"D" JOB: BC80-2204-A2 CI#5 CI% 1-20







1/4" = 1'-0"



!! ATTENTION !!


NOTE: IT IS THE RESPONSIBILITY OF THE BUILDER TO
COORDINATE THE INSTALLATION OF ALL WATER PROOFING
METHODS NECESSARY TO PROVIDE A WATER TIGHT BUILDING
ENVELOPE. REFER TO MFR INSTALLATION RECOMMENDATION
FOR ALL SELECTED WATERPROOFING MATERIALS, FLASHING,
SEALERS AND AD-MIX COMPONENTS





## MECHANICAL DISCLAIMER

ANY DUCT ROUTING AND HVAC EQUIPMENT SHOWN ON THESE DRAWINGS ARE DIAGRAMMATIC ONLY. THE BUILDER IS SOLELY RESPONSIBLE FOR COORDINATING ALL ASPECTS OF MECHANICAL INSTALLATION WITH ALL TRADES. THE BUILDER SHALL COORDINATE BETWEEN THE PRE ENGINEERED TRUSS MFR AND/OR FRAMING REQUIREMENTS WITH THE MECHANICAL CONTRACTOR TO ENSURE ADEQUATE SPACE FOR DUCT ROUTING AND EQUIPMENT PLACEMENT AND SUPPORT. HVAC INSTALLATION SHALL BE INSTALLED ACCORDING TO ALL CURRENT STATE AND LOCAL




ELECTRICAL PLAN

## MECHANICAL DISCLAIMER

ANY DUCT ROUTING AND HVAC EQUIPMENT SHOWN ON THESE DRAWINGS ARE DIAGRAMMATIC ONLY. THE BUILDER IS SOLELY RESPONSIBLE FOR COORDINATING ALL ASPECTS OF MECHANICAL INSTALLATION WITH ALL TRADES. THE BUILDER SHALL COORDINATE BETWEEN THE PRE ENGINEERED TRUSS MFR AND/OR FRAMING REQUIREMENTS WITH THE MECHANICAL CONTRACTOR TO ENSURE ADEQUATE SPACE FOR DUCT ROUTING AND EQUIPMENT PLACEMENT AND SUPPORT. HVAC INSTALLATION SHALL BE INSTALLED ACCORDING TO ALL CURRENT STATE AND LOCAL

MECHANICAL CODES.



DETERMINE WHETHER OR NOT THE FOLLOWING ITEMS ARE INCLUDED:

> LIGHTING OR ELECTRONICS (LCD DISPLAY OR LIGHTING AUTOMATION PUSH BUTTON CONTROLLER)

VOLUME CONTROL KNOB

\* USE MAX OF 6 GANG BOXES. FOR GANG BOXES OF 3 OR MORE THAT ARE LOCATED ON

BLOCK WALL, CHIP OUT THE BLOCK TO ACCOMMODATE DEEPER

NOTE: ALL DIMENSIONS ARE FOR ROUGH FRAMING

ELECTRICAL DETAILS

SCALE: 1/2"=1'-0" UPDATED 10/14/16

## ELECTRICAL LEGEND


- → DUPLEX OUTLET (110V AT 12" OR AS NTD) → DUPLEX OUTLET (110∨ AT 39") \*
- DUPLEX OUTLET (110V AT 43") \*
- ➡ DUPLEX OUTLET (110V AT 45") \*
- ⇒ SPLIT DPLX OUTLET (110V AT 12") TOP IS 'HOT'
- ₩EATHERPROOF DPLX OUTLET (110V AT 12") TOP IS 'HOT'
- $\hat{\mathbb{P}} \oplus \mathsf{OUTLET} \; \mathsf{W/} \; \mathsf{USB} \; \mathsf{PORTS}(110\mathsf{V} \; \mathsf{AT} \; 12" \; \mathsf{OR} \; \mathsf{AS} \; \mathsf{NTD})$
- RECESS FLOOR OUTLET
- RECESS CEILING OUTLET (110V)
- → SM SEE ELEC DTL


   THE SEE ELEC DTL

    $\theta^{m}$  3-MAY SM SEE ELEC DTL
- $0^{4}$  4-MAY SM SEE ELEC DTL I-GANG COMBINATION FAN / LIGHT SWITCH
- $\frac{8}{100}$  OCCUPANCY/MOTION DETECTOR SWITCH
- -O PUSH-BUTTON FOR GARAGE DOOR AT 60"
- DIMMER SM AT 36" PUSH-BUTTON DOORBELL
- CLG MNT LGT FIXTURE
- T" SURFACE MNT 3000K, 1000 LUMEN, LED FIXTURE
- SURFACE MNT FIXTURE
- WALL MNT FIXTURE
- © 6" ROUND RECESS 3000K LED RETROFIT TRIM W/OPEN BAFFLE
- 6" ROUND RECESSED ULTRA THIN LED O, 4" MINI ROUND RECESSED ULTRA THIN LED
- O 4" MINI ROUND RECESS 3000K LED RETROFIT TRIM WOPEN BAFFLE
- 4" MINI ROUND RECESS 3000K LED EYEBALL TRIM
- 6" ROUND SLOPE CLG RECESS WITH 3000K LED BULB
- ▼▼ TELEPHONE OUTLET AT 12" OR AS NOTED
- CLG FAN/LIGHT PREMIRE AND SMITCHES SMOKE DETECTOR OR COMBO SMOKE & CARBON MONOXIDE DETECTOR PER CODE
- UNDER CAB LED 9" UNDER CAB LED 22"
- UNDER CAB LED 14" UNDER CAB LED 30" 24 LED 48 LED 24" OR 48" CLG MNT 3000K, LED FIXTURE
- 24" \$ 36" VANITY LIGHTING (SEE SPECS) EXHAUST FAN / LIGHT FIXTURE COMBO
- EXHAUST FAN
- SOFFIT MNT FLOOD LIGHT
- OLG MNT SPEAKER
- # CHIMES ELEC PANEL
- RETURN AIR GRILLE
- SUPPLY DIFFUSER LINEAR DIFFUSER LENGTH IN INCHES
- THERMOSTAT TP SECURITY PAD
- NOTE: ALL OUTLETS ABOVE COUNTERS SHALL BE MOUNTED HORIZONTALLY
- NOTE: ALL 125V, 15 AND 20 AMP OUTLETS TO BE TAMPER-RESISTANT IN AREAS SPECIFIED BY NEC 2014 406.11.
- NOTE: ALL EXTERIOR OUTLETS, OUTLETS IN GARAGE, WALL OUTLETS IN KITCHENS AND BATHROOMS AND ALL OUTLETS WITHIN 6'-0" OF A WATER SOURCE SHALL BE G.F.I. ALL NON-GFI OR 220V OUTLETS ARE PROTECTED BY AN ARC-FAULT
- NOTE: LIGHTS, FANS, SMOKE DETECTORS, A/C SUPPLIES AND RETURN AIRS TO BE PLACED ON CENTERLINES OF DOORS, MDMS AND HALLMAYS, TYP UNO

CIRCUIT INTERRUPTER. ALL HEIGHTS TO CENTERLINE AFF.


- NOTE: COMBINATION SMOKE & CARBON MONOXIDE DETECTORS SHALL BE INSTALLED PER NFPAT2 CHAPTER 29
- NOTE: COORDINATE LOCATION OF ALL REQ. ELECTRICAL, CABLE, AUDIO/VIDEO & DATA RECEPTACLES W/ MOUNTING HARDWARE & MFR. INSTALLATION REQ. FOR ALL FLAT PANEL








MOULDING PROFILES & DETAILS PLAN: PLAN: PLAN: 1752F-25-01-"D"
JOB: BC88-2204-A2
Cites Cite 1-20





## GENERAL NOTES:

THE TOE KICK IS 4".

CABINET ELEVATIONS AND LIGHTING ARE GRAPHIC REPRESENTATIONS ONLY. REFERENCE SHOULD BE MADE TO THE ELECTRICAL SHEET, CABINET MFR DRAWINGS AND SPECS FOR FURTHER INFORMATION. REFER TO CABINET SHOP DRAWINGS FOR CABINET & VANITY TOP DIMENSIONS.

PLUMBING, TILE, BASE MLDG, DOOR CASING & DECORATIVE LIGHTING & DECORATIVE MIRRORS ARE ILLUSTRATED FOR LOCATION PURPOSES ONLY. PLEASE REFER TO COMMUNITY STANDARDS FOR SIZES & SPECS.