

MEMORANDUM

To:	All Concerned Parties	Date:	January 29, 2025
From:	Austin Blazs	Project:	24-0379.01
Subject:	Finished Floor Elevation letter for Lot 1, Preserve at Laural Lake, Unit 1		

Please accept this memorandum as my certification that the elevation of the lowest finished floor of the new residence constructed on Lot 1, Preserve at Laural Lake, Unit 1, as per plat recorded in Plat Book 9, Pages 19-25, was field measured on January 29, 2025, to be **116.12** feet. Said residence is in compliance with the Zoning setback requirements. The benchmark used as a basis for this measurement is based on NGS Data Point BD1031, with a designation of I75 71 A14.

The minimum finished floor elevation required for Lot 1, per an Elevation Letter provided by Christopher A. Potts, P.E. with LJA Engineering, is **115.80** feet.

Austin Blazs

Digitally signed by Austin Blazs
 DN: CN=Austin Blazs, O=Austin Blazs, L=Hawthorne, S=Florida, C=US
 Date: 2025.01.30 10:28:05-05'00'

Austin Blazs, PSM
 Registered Florida Surveyor and Mapper Certificate Number 7401

