

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

March 29, 2022

Kevin Bedenbaugh, Jr.
Plumb Level Construction
386.365.5264
plumblevelconstruction@gmail.com

re: ELEVATION LETTER – PARCEL 23-35-16-02279-104, LOT 4, TURKEY CREEK UNIT 1,
COLUMBIA COUNTY, FL

As requested, I inspected the building at the above referenced site. The plat lists the minimum finished floor elevation to be 161.50'. According to the attached elevation certification by Britt Surveying and Mapping, LLC dated March 29, 2022, the finished floor elevation is 159.65'.

I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A0141
0D0000017EB6D9
24CE0005954C,
cn=Carol
Chadwick
Date: 2022.03.29
20:21:57 -04'00'



Carol Chadwick, P.E.

Attachment: Elevation Certification



Britt Surveying and Mapping, LLC

1438 SW Main Boulevard • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/29/2022

L-28488

Permit # 000043447

Plumb Level Construction

Re: Lot 4 Turkey Creek

To Whom It May Concern:

The elevation of the foundation on Lot 4 is found to be 159.65 feet. The centerline of NW Turkey Run Court is found to be 158.2 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

L. Scott Britt

LS 5757