

# 2020 - AIR BARRIER AND INSULATION INSPECTION COMPONENT CRITERIA

TABLE 402.4.1.1

## AIR BARRIER AND INSULATION INSPECTION COMPONENT CRITERIA<sup>a</sup>

| Project Name: J-10346 - C-2623                          |  | Builder Name:   |  |
|---|--|---|--|
| Street:   |  | Permit Office:  |  |
| City, State, Zip: Columbia County, FL,                  |  | Permit Number:  |  |
| Owner:  |  | Jurisdiction:   |  |
| Design Location: FL, Gainesville                        |  | County: Columbia(Florida Climate Zone 2)  |  |
|   |  | CHECK   |  |
| COMPONENT   | AIR BARRIER CRITERIA   | INSULATION INSTALLATION CRITERIA  |  |
| General requirements                                    | A continuous air barrier shall be installed in the building envelope. The exterior thermal envelope contains a continuous air barrier. Breaks or joints in the air barrier shall be sealed.  | Air-permeable insulation shall not be used as a sealing material.   |  |
| Ceiling/attic   | The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier shall be sealed. Access openings, drop down stairs or knee wall doors to unconditioned attic spaces shall be sealed.                        | The insulation in any dropped ceiling/soffit shall be aligned with the air barrier.   |  |
| Walls   | The junction of the foundation and sill plate shall be sealed. The junction of the top plate and the top of exterior walls shall be sealed. Knee walls shall be sealed.  | Cavities within corners and headers of frame walls shall be insulated by completely filling the cavity with a material having a thermal resistance of R-3 per inch minimum. Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier.  |  |
| Windows, skylights and doors                            | The space between window/door jambs and framing, and skylights and framing shall be sealed.  |   |  |
| Rim joists  | Rim joists shall include the air barrier.  | Rim joists shall be insulated.  |  |
| Floors (including above-garage and cantilevered floors) | The air barrier shall be installed at any exposed edge of insulation.  | Floor framing cavity insulation shall be installed to maintain permanent contact with the underside of subfloor decking, or floor framing cavity insulation shall be permitted to be in contact with the top side of sheathing, or continuous insulation installed on the underside of floor framing and extends from the bottom to the top of all perimeter floor framing members. |  |
| Crawl space walls                                       | Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.   | Where provided instead of floor insulation, insulation shall be permanently attached to the crawlspace walls.   |  |
| Shafts, penetrations                                    | Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed.   |   |  |
| Narrow cavities   |  | Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity spaces.  |  |
| Garage separation                                       | Air sealing shall be provided between the garage and conditioned spaces.   |   |  |
| Recessed lighting                                       | Recessed light fixtures installed in the building thermal envelope shall be sealed to the finished surface.  | Recessed light fixtures installed in the building thermal envelope shall be air tight and IC rated.   |  |
| Plumbing and wiring                                     |  | Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring.  |  |
| Shower/tub on exterior wall                             | The air barrier installed at exterior walls adjacent to showers and tubs shall separate them from the showers and tubs.  | Exterior walls adjacent to showers and tubs shall be insulated.   |  |
| Electrical/phone box on exterior walls                  | The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.  |   |  |
| HVAC register boots                                     | HVAC supply and return register boots that penetrate building thermal envelope shall be sealed to the sub-floor, wall covering or ceiling penetrated by the boot.  |   |  |
| Concealed sprinklers                                    | When required to be sealed, concealed fire sprinklers shall only be sealed in a manner that is recommended by the manufacturer. Caulking or other adhesive sealants shall not be used to fill voids between fire sprinkler cover plates and walls or ceilings. |   |  |

a. In addition, inspection of log walls shall be in accordance with the provisions of ICC-400.