

From: [Jeremy Tanner](#)
To: [Columbia County Building and Zoning Info](#)
Subject: Attn Troy: Solomon App #61152
Date: Monday, August 28, 2023 11:15:36 AM
Attachments: [image001.png](#)

Good morning,

Per our conversation this morning, the addition will be 31.15 ft. from the property line and 6ft from the setback of 25ft. The home is in Flood zone AE and the Base Floor Elevation is 35.1. The concrete pad under the home is at 26.24ft and the bottom of the floor joist are at 10ft. This puts the floor joist at 1.24ft above the BFE. The interior floor is roughly 3.25ft. above the BFE. Let me know if you need anything else.

Thank you.

