29



Donald F. Lee & Associates, Inc.

140 NW Ridgewood Avenue Lake City, Florida 32055

PH 386-755-6166 FAX 386-755-6167 email: donald@dfla.com website: www.dfla.com Highway & Route Surveys

Topographic Surveys

- Land & Subdivision Surveys

Control Surveying

Since 1984

DATE: Thursday, November 29, 2012

TO: Columbia County Building Department

CC: Bryan Zecher Construction

FROM: Tim Delbene - Donald F. Lee & Associates

RE: Floor Elevation Check - Lot 33, Oaks of Lake City Phase 1 - Permit # 30596

This is to Certify that elevations were obtained for a foundation under construction on the above referenced parcel of land. The results are as follows:

House slab elevation: 86.35 feet

The record subdivision plat for "Oaks of Lake City Phase 1" indicates that the Minimum Floor Elevation (MFE) for this lot, as set by the project engineer for the development, is 84.0 feet. Elevations are based on NAVD1988 datum.

SIGNED:

Timothy A. Delbene, PSM

Florida Regl Cert. No. LS 5594