



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/07/2024

L-30239

Permit # 000049114

Re: Lot 21 Oaks of Lake City Phase 1

Bryan Zecher Construction

To Whom It May Concern:

The finished floor elevation on Lot 21 is found to be 91.32 feet. The building permit states that the MFE will be above 85 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt

LS 5757

