



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/13/20

Permit # 000039485

L-26515


Re: Lot 25 Turkey Creek

Don Little Construction

To Whom It May Concern:

The elevation of the foundation on Lot 25 is found to be 159.65 feet. The highest adjacent grade is 159.1 feet and the lowest adjacent grade is 159.1 feet. The centerline of NW Turkey Creek Way is established to be 157.87 feet. The centerline of NW Gobbler Drive is established to be 157.82 feet. All elevations shown hereon are based on NAVD 88 datum. The permit update shows a required elevation of 158.12 feet.

Sincerely,



L. Scott Britt
LS 5757