



9th JULY 2025

BUILDING OFFICIAL / INSPECTOR
COUNTY BUILDING DEPT.

RE: PLUMB LEVEL CONST. / REVIS RESIDENCE

TO WHOM IT MAY CONCERN:

WHERE SIMPSON HT5KT AT GARAGE DOORS ARE NOT USEABLE DUE TO SIZE RESTRAINTS,
USE 1/2" THREADED ROD, DRILLED AND EMBEDDED IN SLAB 6" & SET IN EPOXY. RODS WILL EXTEND
UP WALL AND THROUGH TOP PLATES WITH 2" WASHER & NUT ON TOP OF WALL FRAMING.

REGARDS,

NICHOLAS GEISLER, ARCHITECT ARO007005

