

#30269

**Mark D. Duren and
Associates, Inc.
Professional Surveyor and Mapper**

1604 SW Sisters Welcome Road
Lake City, FL 32025
386-758-9831 Phone
386-758-8010 Fax

OK
BKK
17 Oct. 2012

July 30, 2012

Adam's Construction
Columbia County Building and Zoning Department

To Whom It May Concern,

I hereby certify that the elevation of the top of the concrete block stem walls constructed on Lot 14 of "Rolling Meadows", a subdivision as per the plat thereof recorded in Plat Book 8, Pages 45 and 46, public records of Columbia County, Florida, is 106.13 feet. The location of the stem walls checked for this certification is near the area on the north side of the foundation which should be near the front entrance to the structure. The record plat of the subdivision states that the minimum floor elevation of this lot is 106.00'. No elevation datum is stated on the plat. Our elevation data was obtained from the finished floor of the dwelling on Lot 13 which was provided to us by Adam's Construction. The stated elevation of the floor on Lot 13 is 107.48 feet as provided to me.

Field survey date was July 27, 2012. Field Book 208 page 1. WO# 12-168.

Tax parcel No. 15-4S-16-03023-514, 405 SW Morning Glory Drive.



Mark D. Duren, LS 4708
Florida Licensed Surveyor and Mapper