

May 9, 2019

Aaron Simque Homes
333 SW Rosemary Drive
Lake City, FL 32025

Subject: Permit # 37860 - Lot 15, Preserve at Laurel Lake, Unit 1


Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 15, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 114.5'.
- The elevation of the concrete foundation is at 115.7', being 1.2' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM