


Fort White Park

LOT 22




FLOOR PLAN

SCALE: 1/4" = 1 FT.

AREA SUMMARY

CONDITIONED	1696 SF
GARAGE	420 SF
ENTRY	41 SF
REAR PORCH	200 SF
TOTAL ROOF	2357 SF



SITE PLAN

SCALE: 1 IN. = 60 FT.

GENERAL NOTES

- See Wind Load Detail Sheet A-4 and Wind Engineer's Notes for data pertaining to Wind Design and compliance w/ Florida Building Code.
- All concrete used to be 2500 PSI strength or greater.
- HVAC duct and unit size/design is by-engineered shop drawings from the AC contractor.
- Windows to be alum. framed and double glazed. Sizes shown are nominal and may vary with manufacturer.
- Roof Truss design is the responsibility of the supplier.
- The Truss Manufacturer shall prepare Shop Drawings indicating Truss placement, Girder locations, Truss-to-Truss Connections and any point loads. The Contractor shall notify the Designer of any point loads in excess of 20k for End Modification.
- Site analysis or preparation information is not a part of this plan and is the responsibility of the owner.
- Cabinet and millwork detail is not a part of this plan. The plan is a general design and details shall be the responsibility of the owner and/or contractor.

Index to Sheets

SHEET 1	FLOOR PLAN + SITE PLAN + GEN. NOTES
SHEET 2	ELEVATIONS
SHEET 3	FOUNDATION + SECTIONS
SHEET 4	ENGINEERING
SHEET 5	ELECTRICAL

FILE COPY

WINDLOAD ENGINEER: Huey Hawkins, PE No. 33665, Fort White, FL

CERTIFICATION: These plans and "Windload Engineering", Sheet A-4, attached, comply with Florida Building Code Residential 2004, Section R301.2.1 to the best of my knowledge.


[Signature] Date: 9/6/07

A-1

FILE 07-01G	HUEY HAWKINS	SHEET: 1 OF 5
DATE: 8-10-07		CAD FILE: 0701G
DRAWN: T A D	PREPARED BY: TIM DELBENE Drafting + Technical Services	REV:
CHECK: T A D	192 SW Bagwood Cir. Lake City, FL 32025 Phone: (386) 755-5691	REV:


Fort White Park

LOT 22




FRONT ELEVATION

SCALE: 1/4 IN. = 1 FT.




RIGHT ELEVATION

SCALE: 1/4 IN. = 1 FT.



LEFT ELEVATION

SCALE: 1/4 IN. = 1 FT.



REAR ELEVATION

SCALE: 1/4 IN. = 1 FT.

ATTIC VENTILATION

Enclosed attics and enclosed rafter spaces formed where ceilings are applied directly to the underside of roof rafters shall have cross ventilation for each separate space by ventilating openings protected against the entrance of rain. Ventilating openings shall be provided with corrosion-resistant wire mesh, with a 1/8 inch (3.2 mm) minimum to 3/4 inch (6.4 mm) maximum openings.




The total net free ventilating area shall not be less than 1 to 150 of the area of the space ventilated except that the total area is permitted to be reduced to 1 to 300, provided at least 50 percent and not more than 80 percent of the required ventilating area is provided by ventilators located in the upper portion of the space to be ventilated at least 3 feet (914 mm) above eave or cornice vents with the balance of the required ventilation provided by eave or cornice vents.

WINDLOAD ENGINEER: Huey Hawkins, PE No. 33465, Fort White, FL

CERTIFICATION: These plans and "Windload Engineering", Sheet A-4, attached, comply with Florida Building Code Residential 2004, Section R301.2.1 to the best of my knowledge.

Date: 9/6/07

A-2



SLAB OPTIONS:

OPTION 1 - Use 6x6 10/10 WWM reinforcing on chair supports at 3' O.C.


OPTION 2 - Use Synthetic Fiber reinforced concrete.

SHEATHING NAILING
WALLS - 4 IN. EDGES + 8 IN. FIELD
ROOF - 6 IN. EDGES + 12 IN. FIELD
4 IN. GABLES

TYPICAL WALL SECTION

GENERAL TRUSS NOTES:

- TRUSSES SHALL BE DESIGNED BY A LICENSED ENGINEER AND IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL FOREST PRODUCTS ASSOCIATION MANUAL FOR "STRESS-RATED LUMBER AND ITS CONNECTIONS" LATEST ED. ALONG W/ THE "TRUSS PLATE INSTITUTE" SUGGESTED GUIDELINES FOR TEMPORARY AND PERMANENT BRACING AND HANDLING OF TRUSSES. TRUSS SHOP DRAWINGS SHALL INCLUDE TRUSS DESIGN, PLACEMENT PLANS, DETS. + TRUSS TO TRUSS CONNECTIONS.
- TRUSS SHOP DRAWINGS SHALL BE SIGNED + SEALED BY THE DESIGNING ENGINEER.





WINDLOAD ENGINEER: Huey Hawkins, PE No. 33665, Fort White, FL

CERTIFICATION: These plans and "Windload Engineering", Sheet A-4, attached, comply with Florida Building Code Residential 2004, Section R301.2.1 to the best of my knowledge.

Date: 9/6/07

A-3

FILE: 07-01G	HUEY HAWKINS	SHEET: 3 OF 5
DATE: 8-10-07		JAD FILE: 0701G
DRAWN: TAD	PREPARED BY: TIM DELBENE	REV:
CHECK: TAD	Drafting + Technical Services	REV:
	192 SW Sagewood Cir. Lake City, FL 32024	
	Phone: (386) 755-5591	



ENGINEER'S NOTES:

- The report establishes the minimum requirements for wind load stability. It is the owner/builder's responsibility to provide materials and construction techniques which comply with SBC requirements for the stated wind velocity. It is the builder's responsibility to provide a continuous load path from trusses to foundation.
- Since truss engineering was not complete at the time of this analysis, it is the builder's responsibility to select uplift connections based on truss engineering uplift and provide footings for interior bearing wall. Builder is to furnish truss engineering to wind load engineer for review of truss reactions on the building structure. Strap 2x6 rafters with min uplift connection 415b each end, 2x8 rafters 700b each end.
- Site analysis and preparation information is not part of this plan and is responsibility of the owner. All foundations and footings are designed for stable soil conditions with 1000 psf bearing capacity. It is the owner's / builder's responsibility to verify soil and clean fill are compacted to provide 1000 psf minimum bearing capacity or to request foundation design based on actual site conditions.
- Manufacturers and product number for connectors, anchors, and reinforcement are listed for example not endorsement. An equivalent device of the same or other manufacturer can be substituted for any devices listed in the example tables as long as it meets the required load capacities. Manufacturer's installation instructions must be followed to achieve rated loads.
- Anchor bolts - A-307, Minimum embedment: 7" in concrete or reinforced bond beam, 15" in grouted CMU.
- Concrete - Minimum compressive strength $F_c = 2500$ psi.
- Rebar - Grade 40 deformed bars, $F_y = 36$ ksi. All laps 40" Db (25" for #5) unless otherwise specified.
- Nails - All nails are common nails unless otherwise specified or accepted by SBC test reports as having equal structural values.

WALL STUD TABLE

STUDS ARE SPRUCE/PINE/FIR AT 16 IN. O.C.

1 - 2 : 4	TO 10 FT. WALL HEIGHT
2 - 2 : 4	TO 12.5 FT. WALL HEIGHT
3 - 2 : 4	TO 16.5 FT. WALL HEIGHT
1 - 2 : 6	TO 16 FT. WALL HEIGHT
2 - 2 : 6	TO 21 FT. WALL HEIGHT

TOP PLATE 1 2 - 2 X 4 (OR 2 X 6) SPRUCE/PINE/FIR
BOTTOM PLATE 1 2 - 2 X 4 (OR 2 X 6) PRESS. TREATED BEARING ON FOUNDATION WALL.

ROOF SYSTEM DESIGN

THE SEALIN THESE PLANS FOR COMPLIANCE WITH FBC 2001, SECTION 1606 IS USED ON REACTIONS, UPLIFTS, AND BEARING LOCATIONS IN TRUSS ENGINEERING SUBMITTED TO THE WIND LOAD ENGINEER. IT IS THE RESPONSIBILITY OF THE BUILDER TO CHECK ALL DETAILS OF THE COMPLETE ROOF SYSTEM DESIGN SUBMITTED BY THE TRUSS MANUFACTURER AND HAVE IT SIGNED AND SEALED BY A DESIGN PROFESSIONAL FOR CORRECT APPLICATION OF FBC 2001 REQUIRED LOADS. AN ANY SPECIAL LOADS, THE BUILDER IS RESPONSIBLE TO REVIEW EACH INDIVIDUAL TRUSS MEMBER AND THE TRUSS ROOF SYSTEM AS A WHOLE AND TO PROVIDE RESTRAINT FOR ANY LATERAL BRACING. IE BUILDER SHOULD USE CARE CHECKING THE ROOF DESIGN BECAUSE THE WIND LOAD ENGINEER IS SPECIFICALLY NOT RESPONSIBLE FOR THE TRUSS LAYOUT WHICH WAS CREATED BY THE TRUSS MANUFACTURER AND THE TRUSS DESIGNER ALSO DENIES RESPONSIBILITY FOR THE LAYOUT PER NOTES ON THEIR SEALED TRUSS SHEETS.

BUILDER'S RESPONSIBILITY:

THE BUILDER AND OWNER ARE RESPONSIBLE FOR THE FOLLOWING, WHICH ARE SPECIFICALLY NOT PART OF THE WIND LOAD ENGINEER'S SCOPE OF WORK.

- CONFIRM SITE CONDITIONS, FOUNDATION BEARING CAPACITY, GRADE AND BACKFILL HEIGHT, WINDSPEED AND DEBRIS ZONE, AND FLOOD ZONE.
- PROVIDE MATERIALS AND CONSTRUCTION TECHNIQUES WHICH COMPLY WITH FBC 2001 REQUIREMENTS FOR THE STATED WIND VELOCITY AND DESIGN PRESSURES.
- PROVIDE A CONTINUOUS LOAD PATH FROM TRUSSES TO FOUNDATION. IF YOU BELIEVE THE PLAN OMI A CONTINUOUS LOAD PATH CONNECTION, CALL THE WIND LOAD ENGINEER IMMEDIATELY.
- VERIFY THE TRUSS MANUFACTURER'S SEALED ENGINEERING INCLUDES TRUSS DESIGN, PLACEMENT PLUS, TEMPORARY AND PERMANENT BRACING DETAILS, TRUSS-TO-TRUSS CONNECTIONS, AND UPLIFT AND REACTION LOADS FOR ALL BEARING LOCATIONS. SELECT UPLIFT CONNECTIONS AND PROVIDE FOOTINGS BASED ON TRUSS ENGINEERING REACTIONS. FURNISH TRUSS ENGINEERING TO WIND LOAD ENGINEER IN REVIEW OF TRUSS REACTIONS.

TRUSS ANCHOR TABLE

OBTAIN UPLIFT REQ. FROM TRUSS MANUFACTURER'S ENGINEERING

UPLIFT LBS.	TOP CONNECTOR *	BOTTOM CONNECTOR *
< 415	H2-5 10-8d	415 NO SPECIAL CONNECTOR REQ.
< 750	H16 6-10d, 1-1/2"	750 NO SPECIAL CONNECTOR REQ.
< 905	H10 16-8d, 1-1/2"	905 NO SPECIAL CONNECTOR REQ.
< 1250	H16 10-10d, 1-1/2"	1250 SPH4 W/10-10d, 1-1/2" + 1/2" AB 970
< 1245	HTS20 24-10d, 1-1/2"	1245 LTT19 W/8-16d + 1/2" AB 1080
< 2490	2-HTS20 24-10d, 1-1/2"	2490 HD2A-2.5", 5/8" AB 2565

UPLIFT GREATER THAN 2500 LBS. REQUIRES ENGINEERING APPROVAL

* MODEL NUMBERS SHOWN ARE FOR SIMPSON CONNECTORS. THESE ARE LISTED AS EXAMPLES + NOT FOR ENDORSEMENT. OTHER MANUFACTURER'S CONNECTORS WITH SUFFICIENT LOAD CAPACITY MAY BE SUBSTITUTED. FOLLOW MANUFACT. INSTRUCTIONS.

DESIGN DATA

WIND LOADS ARE PER FLORIDA BUILDING CODE 2001, SECTION 1606.2
(FOR ENCLOSED SIMPLE DIAPHRAGM BUILDINGS WITH FLAT, HIPPED AND GABLE-SHAPED ROOFS HAVING A MEAN ROOF HEIGHT NOT EXCEEDING THE LEAST HORIZONTAL DIMENSION OF THE BUILDING OR 50 FT. NOT SITED ON THE UPPER HALF OF A HILL OR ESCARPMENT 60 FT IN EXPOSURE B, 30 FT IN EXPOSURE C AND >10% SLOPE AND UNOBSTRUCTED UPWIND FOR 50% HEIGHT OR 1 MILE WHICHEVER IS LESS.)
BUILDING IS NOT IN THE HIGH VELOCITY HURRICANE ZONE
BUILDING IS NOT IN THE WIND-BORNE DEBRIS REGION
1.) BASIC WIND SPEED = 110 MPH
2.) WIND IMPORTANCE FACTOR = 1
3.) BUILDING CATEGORY = II
4.) INTERNAL PRESSURE COEFFICIENT = N/A (ENCLOSED BUILDING)
5.) COMPONENTS AND CLADDING DESIGN WIND PRESSURES: (DOORS & WINDOWS) +21.8 / -29.1 PSF GARAGE DOOR (N/A) 9x7 +19.3 / -22.2 PSF; 16x7 +18.5 / -20.9
DESIGN LOADS
FLOOR 40 PSF (ALL OTHER DWELLING ROOMS)
30 PSF (SLEEPING ROOMS)
30 PSF (ATTICS WITH STORAGE)
10 PSF (ATTICS WITHOUT STORAGE, <3'12")
ROOF 20 PSF (FLAT OR <4:12)
16 PSF (4:12 TO <12:12)
12 PSF (12:12 AND GREATER)
STAIRS 40 PSF (ONE & TWO FAMILY DWELLINGS)
NO SNOW LOAD
WIND LOADS ARE PER FLORIDA BUILDING CODE 2001, SECTION 1606.2


WINDLOAD ENGINEER: Huey Hawkins, PE No. 33665, Fort White, FL

CERTIFICATION: These plans and "Windload Engineering", Sheet A-4, attached, comply with Florida Building Code Residential 2004, Section R301.2.1 to the best of my knowledge.

[Signature] Date: 9/6/07

A-4

FILE: 07-01G	HUEY HAWKINS	SHEET: 4 OF 5
DATE: 8-10-07		CAD FILE: 0701G
DRAWN: T A D	PREPARED BY: TIM DELBENE	REV:
CHECK: T A D	Drafting + Technical Services	REV:
	192 SW Seagwood Gm. Lake City, FL 33024	
	Phone: (813) 755-5891	



ELECTRICAL PLAN
NOT TO SCALE

ELECTRICAL SYMBOL LEGEND

	= FLOURESCENT LIGHTING FIXTURE.
	= CEILING LIGHT FIXTURE
	= EXTERIOR LIGHTING FIXTURE
	= LIGHT SWITCH
	= THREE-WAY SWITCH
	= 110 V. DUPLEX OUTLET
	= SPECIAL HEIGHT 110 V. DUPLEX OUTLET
	= GROUND FAULT CIRC. OUTLET
	= ARC FAULT CIRC. OUTLET
	= 110 V. SINGLE RECEPTACLE OUTLET.
	= 220 VOLT OUTLET (4 WIRE)
	= FAN LOCATION (CEILING)
	= FAN LOCATION (EXHAUST)
	= SMOKE DETECTOR

ELECTRICAL PLAN NOTES

- WIRE ALL APPLIANCES, HVAC UNITS AND OTHER EQUIPMENT PER MANUF. SPECIFICATIONS.
- CONSULT THE OWNER FOR THE NUMBER OF SEPERATE TELEPHONE LINES TO BE INSTALLED.
- ALL INSTALLATIONS SHALL BE PER NAT'L. ELECTRIC CODE.
- ALL SMOKE DETECTORS SHALL BE 120V W/ BATTERY BACKUP OF THE PHOTOELECTRIC TYPE, AND SHALL BE INTERLOCKED TOGETHER. INSTALL INSIDE AND NEAR ALL BEDROOMS.
- TELEPHONE, TELEVISION AND OTHER LOW VOLTAGE DEVICES OR OUTLETS SHALL BE AS PER THE OWNER'S DIRECTIONS, + IN ACCORDANCE W/ APPLICABLE SECTIONS OF NEC-LATEST EDITION.
- ELECTRICAL CONTR. SHALL BE RESPONSIBLE FOR THE DESIGN + SIZING OF ELECTRICAL SERVICE AND CIRCUITS.
- ENTRY OF SERVICE (UNDERGROUND OR OVERHEAD) TO BE DETERMINED BY POWER COMPANY.

A-5

FILE: 07-016	HUEY HAWKINS	SHEET: 5 OF 5
DATE: 8-10-07		CAT. FILE: 07016
DRAWN: T A D	PREPARED BY: TIM DELBENE Drafting + Technical Services	REV:
CHECK: T A D	192 SW 38thwood Cir. Lake City, FL 32024 Phone: (386) 755-5841	REV: