



# Mechanical Compliance Certificate

## Project Information

Energy Code: 2020 Florida Building Code, Energy Conservation  
Project Title: LAKE CITY MEDICAL CENTER ANCILLARY BUILDING  
Location: Lake City, Florida  
Climate Zone: 2a  
Project Type: New Construction

Construction Site: LAKE CITY MEDICAL CENTER 340  
NW COMMERCE DRIVE  
LAKE CITY, Florida 32055  
Owner/Agent:  
Designer/Contractor:

## Additional Efficiency Package(s)

Credits: 1.0 Required 0.0 Proposed

## Mechanical Systems List

### Quantity System Type & Description

- 1 AHU-1 (Multiple-Zone):  
Heating: 1 each - Other, Electric, Capacity = 162 kBtu/h  
No minimum efficiency requirement applies  
Cooling: 1 each - Single Package DX Unit, Capacity = 305 kBtu/h, Air-Cooled Condenser, Air Economizer  
Proposed Efficiency = 10.00 EER, Required Efficiency: 10.00 EER + 11.6 IEER  
Fan System: AHU-1 -- Compliance (Brake HP and fan efficiency method) : Passes  
  
Fans:  
SAF Supply, Multi-Zone VAV, 6950 CFM, 10.0 motor nameplate hp, 7.6 design brake hp (7.6 max. BHP), 1.00 fan energy index  
EF1-1 Exhaust, Constant Volume, 600 CFM, 0.3 motor nameplate hp, 0.1 design brake hp (0.1 max. BHP), 1.00 fan energy index, fan exception: Single fan < 1 HP or < 0.89 kW  
RAF-1 Relief, Multi-Zone VAV, 5150 CFM, 2.0 motor nameplate hp, 1.5 design brake hp (1.6 max. BHP), 1.00 fan energy index  
Pressure Drop Credits:  
Fully ducted return and/or exhaust air systems, 0.0787 credit
- 1 AHU-2 (Multiple-Zone):  
Heating: 1 each - Other, Electric, Capacity = 179 kBtu/h  
No minimum efficiency requirement applies  
Cooling: 1 each - Single Package DX Unit, Capacity = 353 kBtu/h, Air-Cooled Condenser, Air Economizer  
Proposed Efficiency = 10.00 EER, Required Efficiency: 10.00 EER + 11.6 IEER  
Fan System: AHU-2 -- Compliance (Brake HP and fan efficiency method) : Passes  
  
Fans:  
EF2-3 Exhaust, Constant Volume, 1000 CFM, 0.3 motor nameplate hp, 0.2 design brake hp (0.3 max. BHP), 1.00 fan energy index, fan exception: Single fan < 1 HP or < 0.89 kW  
EF2-2 Exhaust, Constant Volume, 2050 CFM, 0.8 motor nameplate hp, 0.3 design brake hp (0.3 max. BHP), 1.00 fan energy index, fan exception: Single fan < 1 HP or < 0.89 kW  
EF2-1 Exhaust, Constant Volume, 650 CFM, 0.3 motor nameplate hp, 0.1 design brake hp (0.3 max. BHP), 1.00 fan energy index, fan exception: Single fan < 1 HP or < 0.89 kW  
RAF-2 Relief, Multi-Zone VAV, 4025 CFM, 2.0 motor nameplate hp, 1.1 design brake hp (1.1 max. BHP), 1.00 fan energy index  
AHU-2 Supply, Multi-Zone VAV, 7775 CFM, 10.0 motor nameplate hp, 9.0 design brake hp (10.0 max. BHP), 1.00 fan energy index  
Pressure Drop Credits:  
Fully ducted return and/or exhaust air systems, 0.1210 credit
- 1 A/C-1 (Single Zone):  
Heating: 1 each - Other, Electric, Capacity = 28 kBtu/h  
No minimum efficiency requirement applies  
Cooling: 1 each - Split System, Capacity = 24 kBtu/h, Air-Cooled Condenser, Unknown Economizer

## Quantity System Type & Description

Proposed Efficiency = 14.00 SEER, Required Efficiency: 14.00 SEER  
Fan System: A/C-1 | ELECTRICAL ROOM -- Compliance (Motor nameplate HP and fan efficiency method) : Passes

Fans:

AC-1 Supply, Constant Volume, 551 CFM, 0.3 motor nameplate hp, 1.00 fan energy index , fan exception: Single fan < 1 HP or < 0.89 kW

1 A/C-2 (Single Zone):

Heating: 1 each - Other, Electric, Capacity = 28 kBtu/h

No minimum efficiency requirement applies

Cooling: 1 each - Split System, Capacity = 24 kBtu/h, Air-Cooled Condenser, Unknown Economizer

Proposed Efficiency = 14.00 SEER, Required Efficiency: 14.00 SEER

Fan System: A/C-2 -- Compliance (Motor nameplate HP and fan efficiency method) : Passes

Fans:

A/C-2 Supply, Constant Volume, 551 CFM, 0.3 motor nameplate hp, 1.00 fan energy index , fan exception: Single fan < 1 HP or < 0.89 kW

1 WH-1:

Electric Storage Water Heater, Capacity: 50 gallons w/ Circulation Pump

Proposed Efficiency: 0.84 SL, %/h (if > 12 kW), Required Efficiency: 0.84 SL, %/h (if > 12 kW)

1 WH-2:

Electric Storage Water Heater, Capacity: 50 gallons w/ Circulation Pump

Proposed Efficiency: 0.84 SL, %/h (if > 12 kW), Required Efficiency: 0.84 SL, %/h (if > 12 kW)

## Mechanical Compliance Statement

*Compliance Statement:* The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed mechanical systems have been designed to meet the 2020 Florida Building Code, Energy Conservation requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

ANDY BALOGH, P.E.

Name - Title

Signature

3/11/2022

Date