



## Hall's Pump and Well Services, Inc.

904 NW Main Blvd.

Lake City, FL 32055

hallspumpandwell@bellsouth.net

- Lloyd's -

Contractor #

1503

Submitted By

Benjamin D. Dicks

11/21/2019



Parcel ID 02-4S-17E-07481-008

Well Letter of Compliance

Property Owners: Jerry Castagna

Columbia County

Drop pipe size, 1-1/4" inch

4 Inch black steel well casing, 235mm wall thickness

Tank sized, PC 244, 81 gallon, will supply a 23.9 gal. draw down at 40/60 pressure setting.

All wells will have a pump and tank combination that will be sufficient for 1 minute of runtime

If you have any questions please call our office @ 386-752-1854

Pump size 1.5 hp, 230 volt, single ph, pump and motor or 4 in diameter

Benjamin Dicks,

Office Coordinator,

Hall's Pump and Well Services, Inc.

904 NW Main Blvd.

Lake City, FL 32055

(P): (386)752-1854

Thanks,