



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

01/25/2023

Permit # 000045522

L-29202


Re: 03816-317

Whiddon Construction

To Whom It May Concern:

The finished slab elevation is found to be 93.07 feet. The minimum floor elevation per the building permit is shown to be 91.5 feet. All elevations are shown in NAVD 88 datum.

Sincerely,



L. Scott Britt
LS 5757

