

Finish Floor Elevation Requirement\Exemption

Client: Butler M Forest
Contractor: Gibraltar Contracting, LLC
Description: Forest Residence
Parcel ID#: 16-4S-16-03026-118

Foundation Requirements:

For protection against water damage during the 100 year storm event, the minimum finish floor elevation of the proposed structure shall be 12 inches above the existing ground at any point along the perimeter of the proposed structure. In no case shall the finish floor elevation be less than 24 inches above the centerline of the adjacent roadway (SW Upchurch Avenue).

The ground around the proposed structure shall be graded such as to convey all stormwater runoff away from the proposed structure.

Certification:

I, David M. Winsberg PE, certify that the minimum floor elevation (or finish floor elevation) listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations of Columbia County, Florida. Please note that this certification is based upon currently available information regarding present onsite and offsite conditions. Also, this certification is contingent upon all of the requirements of this letter being met.



David M. Winsberg
PE# 68463, CA# 29596
August 30, 2018

