



24 APRIL 2024

BUILDING OFFICIAL
COLUMBIA COUNTY, BUILDING DEPT.
COLUMBIA COUNTY COURTHOUSE ANNEX
LAKE CITY, FLORIDA 32055

RE: BUILDING for REED McDANIALS CONSTRUCTION
PERMIT Nr.: 48324


DEAR SIR:

PLEASE BE ADVISED OF THE FOLLOWING CHANGE IN THE MANER OF
ATTACHMENT OF THE ROOF TRUSSES TO THE CMU WALL:

IN LIEU OF THE DETAIL INCORPORATING A P/T 2X8 PLATE ETWEEN THE
ROOF TRUSSES AND THE CMU WALL IT IS PERMISSIBLE TO DIRECT SET THE
TRUSSES WITH ONLY A 15LB FELT MOISTURE BARRIER BETWEEN THE WOOD
AND THE MASONRY CONSTRUCTION. ATTACHMENT OF THE TRUSSES SHALL
REMAIN THE SAME, WITH EMBEDDED TRUSS ANCHORS IN THE MASONRY BOND
BEAM.

SHOULD YOU HAVE ANY FURTHER QUESTIONS WITH THIS, PLEASE CALL FOR
ASSISTANCE.

YOURS TRULY,
NICHOLAS PAUL GEISLER, ARCHITECT AR0007005



N. P.
GEISLER

Digitally signed by: N. P.
GEISLER
DN: CN = N. P. GEISLER
C = US O = AR0007005
OU = ARCHITECT
Date: 2024.04.24 17:08:
19 -05'00'