

Mark Disosway, P.E.

163 SW Midtown Place, Suite 103 Lake City, FL 32025, Ph (386) 754-5419

8/11/21

Building Department

Re: G-N Construction / Spec Houses - Lot 32 & 33 Fort White Park

To whom it may concern:

This letter is in reference to inspection issues on the above referenced project.

1. On the engineering we provided we called for sheathing nailing for uplift and there for 3" x 3" x 1/4" washers. The builder wanted to use 2" x 2" x 1/8" washers instead. The fix is to install Simpson SP1 @ 48" oc from studs to bottom plate if this is done the 2" x 2" x 1/8" washers are ok.

THIS PDF HAS DIGITAL SIGNATURE
AND ELECTRONIC SEAL. PRINTED
COPIES ARE NOT CONSIDERED
SIGNED OR SEALED. YOU MUST
VERIFY SIGNATURE ON THIS PDF.
[CLICK HERE TO VERIFY.](#)



Mark Disosway, PE
Florida Professional Engineer #53915