

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

August 24, 2021

Isaiah Cully

IC Construction LLC

386.867.0086

isaiahc@bellsouth.net

re: ELEVATION LETTER FINAL INSPECTION – 417 NW HIGH POINT DRIVE, LAKE CITY, FL

As requested, I inspected the grading on the north side of the structure at the above referenced site. A swale had been constructed to prevent precipitation from impacting the home. The swale drains to the road.

I certify that the minimum finished floor elevation specified in a previously letter, along with the grading, will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,

Digitally signed by
Carol Chadwick
DN: c=US,
o=Unaffiliated,
ou=A01410D0000
01711349D4A700
01621F, cn=Carol
Chadwick
Date: 2021.08.24
20:00:23 -04'00'

Carol Chadwick, P.E.

