

GENERAL DESIGN REQUIREMENTS

DESIGN DIMENSIONS SHALL COMPLY WITH SPECIFICATION IN ANS/NSPI 5, ANS/NSPI 6, AND ANS/ASPP 7, ANS/ASPP/ICC 14, ANS/ASPP/ICC 15, RESIDENTIAL INGROUND SWIMMING POOLS BASED ON THE POOL TYPE AND NSPI 3 PERMANENTLY INSTALLED RESIDENTIAL SPA. SEE ANS/NSPI 5, ANS/NSPI 6, AND ANS/ASPP 7 FOR DIVING WATER ENVELOPES REQUIREMENTS. SLIDES SHALL MEET THE MANUFACTURER'S INSTALLATION REQUIREMENTS. ENTRY/EXIT: SHALL COMPLY WITH ANS/NSPI 5 AND NSPI 3. LADDERS, UNDERWATER SEATS, AND SWIMMOUTS (MAX 20" BELOW WATER) CIRCULATION SYSTEM, COMPONENTS AND EQUIPMENT SHALL COMPLY WITH NSF 50. THE MAXIMUM TURNOVER RATE IS 12 HOURS. FILTERS SHALL HAVE AN AIR RELIEF AND PRESSURE GAGE. PUMPS 3 HP AND LESS SHALL MEET ANSI/UL1081, CORROSION RESISTANT WITH STRAINER AND MEET THE REQUIRED FLOW. SURFACE SKIMMERS SHALL MEET NSF 50 AND THERE SHALL BE ONE FOR EVERY 800 SF OF SURFACE AREA. RETURN INLETS SHALL BE A MINIMUM OF ONE FOR EVERY 600 SF. HEATERS SHALL MEET ANSI-Z21.56 OR UL1261 OR UL5599 DISINFECTANT EQUIPMENT SHALL COMPLY WITH NSF 50. PRESSURE TEST PIPING AT 35 PSI FOR 15 MINUTES OR MEET LOCAL CODE IF GREATER.

PIPE SIZING CHART (MAXIMUM)

PIPE	SUCTION	PRESSURE	MAIN SUCTION PIPE SIZE	SKIMMER SUCTION PIPE SIZE	CLEANER/VAC PIPE SIZE	RETURN PIPE SIZE
1 1/2"	33 GPM	65 GPM	1"	1"	1"	1"
2"	60	105	1 1/4"	1 1/4"	1 1/4"	1 1/4"
2 1/2"	90	147	1 1/2"	1 1/2"	1 1/2"	1 1/2"
3"	135	230	2"	2"	2"	2"
4"	235	396	3"	3"	3"	3"

VARIABLE OR DUAL SPEED PUMPS ARE REQUIRED IF THE PUMP EXCEEDS 1 HP. PLUMBING WILL BE DESIGN FOR THE MAX FLOW OF THE PUMP. REFER TO TDH CALCULATIONS FOR VARIABLE OR DUAL SPEED DESIGNS.

ADDITIONAL NOTES

- POOL INSTALLATION SHALL BE BY A QUALIFIED AND LICENSED (APPROVED BY LOCAL BUILDING DEPARTMENT) POOL CONTRACTOR. THE INSTALLATION SHALL CONFORM TO ALL LOCAL BUILDING CODES, IE, PERMITS SPECIFICATIONS, CODES, RULES, RULES, INSPECTION, WORKMANSHIP, ETC.
  - TYPICAL PROPERTIES OF A REINFORCES FIBERGLASS POOL:  
GEL COAT/ISO-NPG MIL APPLICATION 25  
GLASS CONTENT BY WEIGHT 35%  
TENSILE STRENGTH, PSI 16733  
TENSILE ELONGATION 1-2%  
FLEXURAL STRENGTH, PSI 43123  
FLEXURAL MODULUS, PSI (X10^6) 1.37  
COMPRESSIVE STRENGTH, PSI 25300
  - POOL SHELL SHALL BEAR ON UNDISTURBED SOIL, FREE OF PEAT, MUCK, OR OTHER DELETERIOUS MATERIAL OF ANY SIGNIFICANT AMOUNT.
  - BACKFILL MATERIAL MUST NOT CONTAIN ROCKS OR OTHER MATERIALS THAT COULD DAMAGE POOL WALLS.
  - POOL TURNOVER SHALL BE 12 HOURS MAXIMUM WITH HI-RATE RAPID SAND FILTER (MIN. 18" DIAMETER OR 1.75 S.F.) AND PROPERLY GROUNDED. APPROVED PUMP (MIN. 1/2 HP W/29 GPM @ 60 TDH) HAYWARD OR EQUAL.
  - STEPS OR A LADDER SHALL BE PROVIDED AT THE SHALLOW END OF THE POOL.
  - HANDRAILS REQUIRED ON SOME POOLS.
  - INSTALL LOW VOLTAGE LIGHT AS PER NEC 680.
  - DIVING PLATFORMS OR DIVING BOARDS ARE NOT TO BE INSTALLED ON THESE POOLS EXCEPT FOR "THE BIG BLUE KEY" POOL PLAN. THIS POOL MEETS THE ANS/NSPI-5, 2003. DIVING POOL REQUIREMENTS FOR TYPE 1 & TYPE 2 POOLS.
  - DURING A HURRICANE WARNING OR ALERT, THIS POOL SHALL BE FILLED WITH WATER.
  - THESE POOL PLANS MEET OR EXCEED THE ANS/NSPI 5 2003 RESIDENTIAL INGROUND SWIMMING POOL AND ANS/NSPI 3 1999 PERMANENTLY INSTALLED RESIDENTIAL SPA STANDARDS.
- THE FOLLOWING CODES ARE TO BE MET WHERE REQUIRED:  
FLORIDA BUILDING CODE, EIGHTH EDITION - BUILDING 2023  
FLORIDA BUILDING CODE, EIGHTH EDITION - MECHANICAL 2023  
FLORIDA BUILDING CODE, EIGHTH EDITION - PLUMBING 2023  
2020 NATIONAL ELECTRICAL CODE  
98-76 BUILDING CONSTRUCTION ADMINISTRATIVE CODE W/2006 REVISIONS  
ALL APPLICABLE CITY/COUNTY CODES AND ORDINANCES.
- Not to be used for Vinyl Pools




FLORIDA BUILDING CODE R4101

THE POOL CONTRACTOR IS RESPONSIBLE FOR FURNISHING ALL DETAIL DESIGN REQUIREMENTS FOR EACH INDIVIDUAL POOL IN ACCORDANCE WITH THE FLORIDA BUILDING CODE AND ALL CONSTRUCTION SHALL MEET ALL APPLICABLE CODES INCLUDING PLUMBING, ELECTRICAL AND GAS. PIPING SHALL BE SCH. 40 PVC, NSF PW, MAX. PRESSURE VELOCITY 10 FPS, SUCTON 6 FPS. THE POOL PLAN SHALL SHOW THE DESIGN PLUMBING AS PER THE SAMPLE WITH THE INFORMATION REQUIRED SHOWN. SKIMMERS DO NOT REQUIRE PROTECTION AND MUST BE DESIGNED FOR A MINIMUM 25 gpm. THE FOLLOWING SHALL BE LABELED WITH LABEL MARKER TAPE AT THE FILTER LOCATION: PIPES, VALVES, PUMP(S) OFF SWITCH. NO MAIN DRAIN POOLS MUST HAVE 2 SKIMMERS AND INLETS LOW ON THE WALL.



SPECIAL SPA REQUIREMENTS:

- MAXIMUM WATER DEPTH 4'. MAXIMUM SEAT DEPTH 28". MAX
- FLOOR SLOPE 1:12
- STEPS: MIN TREAD 10" X 12", 7" MIN RISER, 12" MAX. RISER EXCEPT THE BOTTOM STEP MAY BE 14" IF IT IS BE UNIFORM. IF THE SPA IS OPERATED INTERMITTENTLY IT SHALL HAVE A ONE HOUR TURNOVER. IF CONTINUOUS A SIX HOUR TURNOVER.
- MAXIMUM TEMPERATURE 104 DEGREES.
- MEET ANS/NSPI ARTICLE XVII, SAFETY INSTRUCTION/SAFETY SIGNS.
- PRESSURE TEST PIPING AT 35 PSI FOR 15 MINUTES OR MEET LOCAL CODE IF GREATER.
- ELECTRICAL REQUIREMENTS:
- WIRING AND BONDING AND ALL ELECTRICAL TO COMPLY WITH CHAPTER 42, FLORIDA BUILDING CODE, SEVENTH EDITION, FBC 2020 AND NEC 2017
- NO OUTLET OR OVERHEAD POWER WITHIN 10' IF WITHIN 15' PROTECT BY GFI, TRANSFORMER MIN. 10' FROM POOL, 8" ABOVE WATER, J BOX 4' FROM POOL, BRASS TO J BOX OR TRANSFORMER WHICH EVER IS FIRST EXCEPT WHERE PVC IS APPROVED.

SB2836, 6-20-07  
FOR BONDING AND GROUNDING SYSTEMS FOR SWIMMING POOLS, THE USE OF AN UNDERGROUND BONDING CONDUCTOR MADE OF #8 AWG. BARE SOLID COPPER WIRE BURIED TO A MINIMUM DEPTH OF 4 INCHES TO 6 INCHES BELOW SUBGRADE, AND 18 TO 24 INCHES FROM INSIDE WALL OF A SWIMMING POOL OR SPA, IS DEEMED A PERMISSIBLE ALTERNATIVE OR EQUIVALENT TO COMPLIANCE WITH S. (680.26(c) OF THE NATIONAL ELECTRICAL CODE.




POOL/SPA, DECK, BEAM, WALL, FLOOR



GENERAL POOL PLAN

Determine System Flow Rate:  
Minimum Flow Rate Required: 35gpm per skimmer (Required: 1 Skimmer per 800 sf)  
Pool Volume: 500 sq. ft x 4 ave. depth x 7.481 gal/cf = 15,000 gallons  
Turnover Time in Hours: 6 hours x 60 min/hr = 360 minutes  
Flow Rate: 15,000 gallons / 360 minutes = 42 gpm



COMPLIES WITH 2023 FLORIDA BUILDING CODE, 8TH EDITION

BRADLEY WARD  
262 SW FOREST GLEN  
LAKE CITY, FL 32025

STANDARD RESIDENTIAL  
FIBERGLASS POOL  
AND/OR SPA DESIGN

G.B. COLLINS ENGINEERING P.A.  
CERTIFICATE OF AUTHORIZATION 27934

AQUATIC ENGINEERING CONSULTANTS  
32707 US HIGHWAY 19 NORTH  
PALM HARBOR, FLORIDA 34684  
GB\_COLLINS@VERIZON.NET  
(727)-442-8443

6-25-2024

DATE

AS SHOWN

SCALE

6-25-2024

DATE

AS SHOWN

SCALE