


ADDENDUM LETTER

BORCHARDT RESIDENCE
258 SE RIPLEY PLACE, LAKE CITY
COLUMBIA COUNTY, FL 32024

The following is an addendum to the Borchardt Residence plans, prepared by Lauri B. Ketring and signed and sealed by T. Brent Whitman, PE # 63178:

1. It is permissible to bore holes in beams and joists for electrical and plumbing work in accordance with the following details:

Holes may up to a maximum diameter of $1/3$ of the depth of the beam/joist, and the hole shall not be within 2 inches of the top/bottom of the beam(see table below).




JOIST/BEAM SIZE	MAX. HOLE DIAMETER (inches)
2x6	1-1/2
2x8	2-3/8
2x10	3
2x12	3-3/4

This item has been digitally
Signed and sealed by

On the date adjacent to the seal

Printed copies of this document
Are not considered signed and
Sealed and the signature must be
Verified on any electronic copies.



Christopher Q. Dicks, P.E. 64766
4037 SE County Road 252
Lake City, FL 32025