

**JAMES ZALESKI P.E 51544**

2305 HAVERHILL RD  
TALLAHASSEE, FL 32312  
PH 850-766-7778

June 4, 2021

The flood map for the selected area is number **12023C0485C**, effective on **02/04/2009**

RE: 329 SW Colony Glen

Sir

The proposed finished floor elevation is 79.0 and the plat calls for a minimum finished floor elevation of 81.00. Per FEMA this is an area of minimal flood. The home will have over 1 foot of fall away from the home on all sides of the house.



I certify that the proposed finished floor elevation listed above will protect the structure at parcel number 06-6S-17-03761-141 against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Please contact me with any questions.

**JAMES ZALESKI** Digitally signed by JAMES ZALESKI  
Date: 2021.06.04 10:08:26 -04'00'

James Zaleski P.E. 51544

