

Newton


STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
APPLICATION FOR CONSTRUCTION PERMIT

Permit Application Number

21-0007

1"=50'

PART II - SITEPLAN



1286.93

9,94A

145' cut

332.11'

140' cut

26

Notes:

Site Plan submitted by:

Plan Approved

Not Approved

Date

By

Columbia County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
ONSITE SEWAGE TREATMENT AND DISPOSAL  
SYSTEM  
APPLICATION FOR CONSTRUCTION PERMIT

PERMIT NO 21-0087  
DATE PAID: 1/6/21  
FEE PAID: 310.00  
RECEIPT #: 1611817

APPLICATION FOR:  
☒ New System ☐ Existing System ☐ Holding Tank ☐ Innovative  
☐ Repair ☐ Abandonment ☐ Temporary ☐

APPLICANT: Roger Newton

AGENT: Jeff Hardee

TELEPHONE: 352 949 0592

MAILING ADDRESS: 6450 NW 12 Ln Chiefland FL 32626

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: 1A BLOCK: 1A SUBDIVISION: Run Island Ranch PLATTED: \_\_\_\_\_

PROPERTY ID #: 25-7-16-04321-074 ZONING: \_\_\_\_\_ I/M OR EQUIVALENT: ☒ Y/N

PROPERTY SIZE: 9.94 ACRES WATER SUPPLY: ☒ PRIVATE PUBLIC ☐ 1-2000GPD ☐ 1-2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? ☒ Y/N DISTANCE TO SEWER: 1A FT

PROPERTY ADDRESS: Run Island Trl Ft White

DIRECTIONS TO PROPERTY: 47 S 71 L SR 27 71 R

CR 138 71 L Run Island Trl to Lt  
on left ~ 400' Past Feather Ln

BUILDING INFORMATION ☒ RESIDENTIAL ☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table 1, Chapter 64E-6, FAC
1	<u>House</u>	<u>3</u>	<u>1664</u>	
2				
3				
4				

☐ Floor/Equipment Drains ☐ Other (Specify) \_\_\_\_\_

SIGNATURE: Jeff Hardee

DATE: 12-23-20





STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
ONSITE SEWAGE TREATMENT AND DISPOSAL  
SYSTEM

PERMIT #: **12-SC-2218583**  
APPLICATION #: **AP1611017**  
DATE PAID: **1/6/21**  
FEE PAID: **316.00**  
RECEIPT #:  
DOCUMENT #: **PR1497899**

CONSTRUCTION PERMIT FOR: OSTDS New  
APPLICANT: RODGER\*\*21-0007 NEWTON  
PROPERTY ADDRESS: RUM ISLAND Fort White, FL 32038  
LOT: TRACT 4 BLOCK: SUBDIVISION: Rum Island Ranches  
PROPERTY ID #: 04321074 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]  
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [ 900 ] GALLONS / GPD New Multi-Chambered Septic CAPACITY  
A [ ] GALLONS / GPD N/A CAPACITY  
N [ ] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]  
K [ ] GALLONS DOSING TANK CAPACITY [ ] GALLONS @ [ ] DOSES PER 24 HRS #Pumps [ ]

D [ 375 ] SQUARE FEET Drainfield SYSTEM  
R [ ] SQUARE FEET N/A SYSTEM  
A TYPE SYSTEM: [x] STANDARD [ ] FILLED [ ] MOUND [ ]  
I CONFIGURATION: [x] TRENCH [ ] BED [ ]

F LOCATION OF BENCHMARK: Nail in tree right of D/F

I ELEVATION OF PROPOSED SYSTEM SITE [ 21.00 ] [ INCHES ] FT [ ] [ ABOVE / BELOW ] BENCHMARK/REFERENCE POINT  
E BOTTOM OF DRAINFIELD TO BE [ 51.00 ] [ INCHES ] FT [ ] [ ABOVE / BELOW ] BENCHMARK/REFERENCE POINT

L  
D FILL REQUIRED: [ 0.00 ] INCHES EXCAVATION REQUIRED: [ ] INCHES

O The system is sized for 3 bedrooms with a maximum occupancy of 6 persons (2 per bedroom), for a total estimated flow of 300 gpd.

T Contractor: Jeff Hardee

H  
E  
R  
SPECIFICATIONS BY: Jeff Hardee TITLE: Septic contractor

APPROVED BY: Sean P. Havens TITLE: Environmental Specialist I Columbia CHD

DATE ISSUED: 01/11/2021 EXPIRATION DATE: 07/11/2022

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC

Page 1 of 3

v 1.1.4

AP1611017

SE1455697

SE