

Columbia County Building Permit Application

CK# 8089

Revised 9-23-04

For Office Use Only Application # 0603-54 Date Received 3/15/06 By G Permit # 24287
Application Approved by - Zoning Official BLK Date 22.03.06 Plans Examiner DKJH Date 3-22-06
Flood Zone 1A X Development Permit N/A Zoning RSF-1 Land Use Plan Map Category RES.U.L.RES
Comments (Truss) Reixed

Applicants Name Maft Cason Phone 752-5152
Address 853 SW Sisters Welcome Rd LC FL 32025
Owners Name Jerome & Denise Hahn Phone 752-5152
911 Address 143 SW Fantasy Glen LC FL 32024
Contractors Name SCCI Phone 752-5152
Address 853 SW Sisters Welcome Rd LC FL 32025
Fee Simple Owner Name & Address _____
Bonding Co. Name & Address _____
Architect/Engineer Name & Address Mark Disorway PO Box 868 LC FL 32056
Mortgage Lenders Name & Address N/A
Circle the correct power company - FL Power & Light - Clay Elec. - Suwannee Valley Elec. - Progressive Energy
Property ID Number 16-45-16-03025-102 Estimated Cost of Construction 12,000
Subdivision Name Meadow Vista Lot 2 Block _____ Unit _____ Phase _____
Driving Directions Hwy 90 West, TL on Hwy 247, TR on Upchurch Rd,
TL on Fantasy Glen, 2nd Lot on R.

Type of Construction Detached Garage Number of Existing Dwellings on Property 1
Total Acreage 1 Lot Size _____ Do you need a - Culvert Permit or Culvert Waiver or Have an Existing Drive
Actual Distance of Structure from Property Lines - Front 130' Side 32' Side 80' Rear 172'
Total Building Height 14' Number of Stories 1 Heated Floor Area 0 Roof Pitch 6/12
TOTAL 864

Application is hereby made to obtain a permit to do work and installations as indicated. I certify that no work or installation has commenced prior to the issuance of a permit and that all work be performed to meet the standards of all laws regulating construction in this jurisdiction.

OWNERS AFFIDAVIT: I hereby certify that all the foregoing information is accurate and all work will be done in compliance with all applicable laws and regulating construction and zoning.

WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOU PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT.

Stanley Crawford
Owner Builder or Agent (Including Contractor)

STATE OF FLORIDA
COUNTY OF COLUMBIA



Sworn to (or affirmed) and subscribed before me

this 15th day of March 2006.

Personally known ✓ or Produced Identification _____

Stanley Crawford
Contractor Signature
Contractors License Number RG-0042896
Competency Card Number 5627
NOTARY STAMP/SEAL

Janet L. Cheek
Notary Signature

Notice of Treatment

Applicator: **Florida Pest Control & Chemical Co. (www.flapest.com)**

Address: 12110 Ave
City: LC Phone: 7521703

Site Location: Subdivision Meadow Vista
Lot # 2 Block# Permit # 24287
Address 143 SW FANTASY Ctry

<u>Product used</u>	<u>Active Ingredient</u>	<u>% Concentration</u>
<input type="checkbox"/> Premise	Imidacloprid	0.1%
<input type="checkbox"/> Termidor	Fipronil	0.12%
<input checked="" type="checkbox"/> Bora-Care	Disodium Octaborate Tetrahydrate	23.0%

Type treatment:

☐ Soil

☒ Wood

<u>Area Treated</u>	<u>Square feet</u>	<u>Linear feet</u>	<u>Gallons Applied</u>
<u>DET GARAGE</u>	<u>864</u>	<u>96</u>	<u>1</u>
<u></u>	<u></u>	<u></u>	<u></u>
<u></u>	<u></u>	<u></u>	<u></u>
<u></u>	<u></u>	<u></u>	<u></u>

As per Florida Building Code 104.2.6 – If soil chemical barrier method for termite prevention is used, final exterior treatment shall be completed prior to final building approval.

If this notice is for the final exterior treatment, initial this line _____.

5-1-06 1100 F254
Date Time Print Technician's Name

Remarks: _____


Applicator - White

Permit File - Canary

Permit Holder - Pink

10/05





16-4S-16-03025-102
 HAHN JEROME T & DENISE A
 10/28/2004 - \$210,000 - 1/Q

Columbia County Property Appraiser

J. Doyle Crews, CFA - Lake City, Florida - 386-758-1083

PARCEL: 16-4S-16-03025-102 HX - SINGLE FAM (000100)


LOT 2 MEADOW VISTA S/D. ORB 803-1448, 960-402, 404, WD 1029-1403.

Name:	HAHN JEROME T & DENISE A	LandVal	\$20,000.00
Site:	FANTASY	BldgVal	\$163,027.00
Mail:	143 SW FANTASY GLN	ApprVal	\$187,197.00
	LAKE CITY, FL 32055	JustVal	\$187,197.00
Sales	10/28/2004 \$210,000.00 / Q	Assd	\$173,089.00
Info	8/6/2002 \$167,400.00 / Q	Exmpt	\$25,000.00
	8/5/2002 \$9,950.00 V / U	Taxable	\$148,089.00

0 0.04 0.08 0.12 mi



This information, GIS Map Updated: 2/7/2006, was derived from data which was compiled by the Columbia County Property Appraiser Office solely for the governmental purpose of property assessment. This information should not be relied upon by anyone as a determination of the ownership of property or market value. No warranties, expressed or implied, are provided for the accuracy of the data herein, its use, or its interpretation. Although it is periodically updated, this information may not reflect the data currently on file in the Property Appraiser's office. The assessed values are NOT certified values and therefore are subject to change before being finalized for ad valorem assessment purposes.



20' UTILITY EASEMENT

334.36'
N1°05'00"E

LOT 4
1.00 Ac. ±

338.54'
N1°05'00"E

LOT 3
1.00 Ac. ±

338.45'

VISTA LANE

128.80' ± 10.0

128.80'

Home
63
38

38
74

338.36'
N1°05'00"E

LOT 1
1.08 Ac. ±

138.81'
S87°12'50"E

338.26'
S.01°05'00"W. 398.29'

N.01°05'00"E. 398.27'

UPCHURCH ROAD

UNPLATTED LANDS
NOT A PART

FOUND 4" CONCRETE
MONUMENT, NO ID.
ON R/W. 25.01'

NE C
S 1/
OF NI
NO M

(20' A
ROADBEI

UTILITY EASEMENT

4"
ELEV. 97.44'
TOP OF

N.87°15'03"W. 415.65'

CTV S.87°15'12"E

414.77'

FOUND 4" CONCRETE
MONUMENT, NO ID.

71
8
71
0
E

This Instrument Prepared by & return to:
Name: NANCY AMY MURPHY, an employee of
TITLE OFFICES, LLC
Address: 1089 SW MAIN BLVD.
LAKE CITY, FLORIDA 32025
File No. 04Y-10007NM

Inst: 2004024440 Date: 11/02/2004 Time: 09:31
Doc Stamp-Deed : 1470.00
MK DC, P. Dewitt Cason, Columbia County B: 1029 P: 1403

Parcel I.D. #: 03025-102

SPACE ABOVE THIS LINE FOR PROCESSING DATA

SPACE ABOVE THIS LINE FOR RECORDING DATA

THIS WARRANTY DEED Made the 28th day of October, A.D. 2004, by JEFFERY T. SHURYAN and LYNN M. SHURYAN, HIS WIFE, hereinafter called the grantors, to JEROME T. HAHN and DENISE A. HAHN HIS WIFE, whose post office address is 143 SW FANTASY GLEN, LAKE CITY, FLORIDA 32055, hereinafter called the grantees: 34 5-71 32024

(Wherever used herein the terms "grantors" and "grantees" include all the parties to this instrument, singular and plural, the heirs, legal representatives and assigns of individuals, and the successors and assigns of corporations, wherever the context so admits or requires.)

Witnesseth: That the grantors, for and in consideration of the sum of \$10.00 and other valuable consideration, receipt whereof is hereby acknowledged, do hereby grant, bargain, sell, alien, remise, release, convey and confirm unto the grantees all that certain land situate in Columbia County, State of FLORIDA, viz:

Lot 2, MEADOW VISTA, according to the map or plat thereof as recorded in Plat Book 6, Page 140, of the Public Records of Columbia County, Florida.

Together with all the tenements, hereditaments and appurtenances thereto belonging or in anywise appertaining.

To Have and to Hold the same in fee simple forever.

And the grantors hereby covenant with said grantees that they are lawfully seized of said land in fee simple; that they have good right and lawful authority to sell and convey said land, and hereby fully warrant the title to said land and will defend the same against the lawful claims of all persons whomsoever, and that said land is free of all encumbrances, except taxes accruing subsequent to December 31, 2003.

In Witness Whereof, the said grantors have signed and sealed these presents, the day and year first above written.

Signed, sealed and delivered in the presence of:

Brenda Styons
Witness Signature

Brenda Styons
Printed Name

Amy Reid
Witness Signature

Amy Reid
Printed Name

Jeffery T. Shuryan
JEFFERY T. SHURYAN L.S.

Address:
32297 GRAND PARKE BLVD., FERNANDINA
BEACH, FL 32034

Lynn M. Shuryan
LYNN M. SHURYAN L.S.

Address:
32297 GRAND PARKE BLVD., FERNANDINA
BEACH, FL 32034

STATE OF FLORIDA
COUNTY OF COLUMBIA

The foregoing instrument was acknowledged before me this 28th day of October, 2004, by JEFFERY T. SHURYAN and LYNN M. SHURYAN, who are known to me or who have produced drivers license as identification.

Brenda Styons
Notary Public
My commission expires _____



BRENDA STYONS
MY COMMISSION # DD 257906
EXPIRES: February 5, 2008
Boarded Thru Budget Notary Services

Inst:2004024440 Date:11/02/2004 Time:09:31

Doc Stamp-Deed : 1470.00

DC, P. Dewitt Cason, Columbia County B:1029 P:1404

This instrument was Prepared By:
STANLEY CRAWFORD CONSTRUCTION, INC.
853 S.W. Sisters Welcome Rd.
Lake City, Florida 32025

PERMIT NO. _____

TAX FOLIO NO.: _____

NOTICE OF COMMENCEMENT

STATE OF FLORIDA
COUNTY OF COLUMBIA

The undersigned hereby gives notice that improvement will be made to certain real Property, and in accordance with Chapter 713, Florida Statutes, the following information Is provided in this Notice of Commencement.

1. Description of property: Meadow Vista Lot 2 143 S.W. Fantasy Glen
Lake City, FL 32024
2. General description of improvement: Construction of Detached Garage
3. Owner information:
Name and address: Jerome T. Hahn
143 S.W. Fantasy Glen
Lake City, FL 32024
- b. Interest in property: Fee Simple
- c. Name and address of fee simple title holder (if other
Than owner): NONE
4. Contractor: Stanley Crawford Construction, Inc.
853 S.W. Sisters Welcome Rd ,Lake City, FL 32025
5. Surety N/A
 - a. Name and address: Inst: 2006006426 Date: 03/15/2006 Time: 14:26



March 6, 2002

Subject: Elk Product Approval Information

All Prestique® and Capstone® products manufactured in Tuscaloosa, AL are certified under the Miami – Dade County Building Code Office (BCCO). These products also meet the requirements for the Florida Building Code since they are MD approved. The following test protocols must be passed by each of the products in order for MD product certification:

ASTM D3462

PA 100 (110 mph uplift and wind driven rain resistance)

PA 107 (Modified ASTM D3161 - 110 mph wind uplift resistance)

The nailing patterns that were used during the PA 100 and PA 107 wind test protocols for the Prestique and Capstone products are listed below. Also listed below are the Miami – Dade Notice of Acceptance Numbers (NOA).

Raised Profile, Prestique High Definition, Prestique 25, or Prestique 30 –

PA 100 = 4 nails

PA 107 = 5 nails

MD NOA# = 01-1226.04

Prestique I 35 or Prestique I* –

PA 100 = 4 nails

PA 107 = 5 nails

MD NOA# = 01-1226.05

Prestique Plus or Prestique Gallery Collection* –

PA 100 = 4 nails

PA 107 = 4 nails

MD NOA# = 01-1226.03

Capstone*

PA 100 = 4 Nails

PA 107 = 4 Nails

MD NOA# = 01-0523.01

* As per the Elk Limited Warranty, six nails are required for the Elk high wind warranty.


If there are any questions please contact:

Mike Reed – Technical Manager
(205) 342-0287

or

Daniel DeJarnette – QA Engineer
(205) 342-0298


ROOFING PRODUCTS SPECIFICATIONS – TUSCALOOSA, AL



**PRESTIQUE®
HIGH DEFINITION®**

High Definition

Product size	13"x 39 1/2"	50-year limited warranty period: non-prorated coverage for shingles and application labor for the initial 5 years, plus an option for transferability*; prorated coverage for application labor and shingles for balance of limited warranty period; 5-year limited wind warranty*.
Exposure	5 1/2"	
Pieces/Bundle	16	
Bundles/Square	4/98.5 sq.ft.	
Squares/Pallet	11	



RAISED PROFILE™

Product size	13"x 38 1/2"	30-year limited warranty period: non-prorated coverage for shingles and application labor for the initial 5 years, plus an option for transferability*; prorated coverage for application labor and shingles for balance of limited warranty period; 5-year limited wind warranty*.
Exposure	5 1/2"	
Pieces/Bundle	22	
Bundles/Square	3/100 sq.ft.	
Squares/Pallet	16	

High Definition

Product size	13"x 39 1/2"	40-year limited warranty period: non-prorated coverage for shingles and application labor for the initial 5 years, plus an option for transferability*; prorated coverage for application labor and shingles for balance of limited warranty period; 5-year limited wind warranty*.
Exposure	5 1/2"	
Pieces/Bundle	16	
Bundles/Square	4/98.5 sq.ft.	
Squares/Pallet	14	

HIP AND RIDGE SHINGLES

Size: 12"x 12"
Exposure: 6 1/2"
Pieces/Bundle: 45
Coverage: 4 Bundles = 100 linear feet

High Definition

Product size	13"x 38 1/2"	30-year limited warranty period: non-prorated coverage for shingles and application labor for the initial 5 years, plus an option for transferability*; prorated coverage for application labor and shingles for balance of limited warranty period; 5-year limited wind warranty*.
Exposure	5 1/2"	
Pieces/Bundle	22	
Bundles/Square	3/100 sq.ft.	
Squares/Pallet	16	

52 Bundles/Pallet
18 Pallets/Truck
936 Bundles/Truck
19 Pieces/Bundle
1 Bundle = 120.33 linear feet

Available Colors: Antique Slate, Weatheredwood, Shakeswood, Sablewood, Hickory, Barkwood**, Forest Green, Wedgewood**, Birchwood**, Sandalwood, Gallery Collection: Balsam Forest*, Weathered Sage*, Sienna Sunset*.

All Prestique, Raised Profile and Seal-A-Ridge roofing products contain Elk WindGuard® sealant. WindGuard activates with the sun's heat, bonding shingles into a wind and weather resistant cover that resists blow-offs and leaks.

Check for availability with built-in StainGuard® treatment to inhibit the discoloration of roofing granules caused by the growth of certain types of algae. Not available in Sablewood.

All Prestique and Raised Profile shingles meet UL® Wind Resistant (UL 997) and Class "A" Fire Ratings (UL 790); and ASTM Specifications D 3018, Type-I; D 3161, Type-I; E 108 and the requirements of ASTM D 3462.

All Prestique and Raised Profile shingles meet the latest Metro Dade building code requirements.

*See actual limited warranty for conditions and limitations.

**Check for product availability.

SCOPE: Work includes furnishing all labor, materials and equipment necessary to complete installation of (name) shingles specified herein. Color shall be (name of color). Hip and ridge type to be Elk Seal-A-Ridge with formula FLX.

All exposed metal surfaces (flashing, vents, etc.) to be painted with matching Elk roof accessory paint.

PREPARATION OF ROOF DECK: Roof deck to be dry, well-seasoned 1" x 6" (25.4mm x 152.4mm) boards; exterior-grade plywood (exposure 1 rated sheathing) at least 3/8" (9.525mm) thick conforming to the specifications of the American Plywood Association; 7/16" (11.074mm) oriented strandboard; or chipboard. Most fire retardant plywood decks are NOT approved substrates for Elk shingles. Consult Elk Field Service for application specifications over other decks and other slopes.

MATERIALS: Underlayment for standard roof slopes, 4" per foot (101.6/304.8mm) or greater: apply non-perforated No. 15 or 30 asphalt-saturated felt underlayment. For low slopes (4" per foot (101.6/304.8mm) to a minimum of 2" per foot (50.8/304.8mm)), use two plies of underlayment overlapped a minimum of 19". Fasteners shall be of sufficient length and holding power for securing material as required by the application instructions printed on shingle wrapper.

For areas where algae is a problem, shingles shall be (name) with StainGuard treatment, as manufactured by the Elk Tuscaloosa plant. Hip and ridge type to be Seal-A-Ridge with formula FLX with StainGuard treatment.

Complete application instructions are published by Elk and printed on the back of every shingle bundle. All

warranties are contingent upon the correct installation as shown on the instructions. These instructions are the minimum required to meet Elk application requirements. In some areas, building codes may require additional application techniques or methods beyond our instructions. In these cases, the local code must be followed. Under no circumstances will Elk accept application requirements less than those contained in its application instructions.

For specifications in CSI format, call 800.354.SPEC (7732) or e-mail specinfo@elkcorp.com.

**SOUTHEAST &
ATLANTIC OFFICE:**
800.945.5551


CORPORATE HEADQUARTERS:
800.354.7732

PLANT LOCATION:
800.945.5545


ELK
www.elkcorp.com

DIRECTIONS FOR APPLICATION


Please read carefully. Failure to follow these instructions may void the product warranty. See specific application instructions for Prestique® Plus and Prestique Gallery Collection™ 110 MPH, and Prestique 190 MPH limited wind warranty requirements.




● **VALLEY CONSTRUCTION OPTION** (California Open and California Closed are also acceptable) NOTE: For complete ARMA valley installation details, see ARMA Residential Asphalt Roofing Manual.



VALLEY CENTER LINE



VALLEY CENTER LINE



VALLEY CENTER LINE

DIRECTIONS FOR APPLICATION

These application instructions are the minimum required to meet Elk's application requirements. Your failure to follow these instructions may void the product warranty. In some areas, the building codes may require additional application techniques or methods beyond our instructions. In these cases, the local code must be followed. Under no circumstances will Elk accept application requirements that are less than those printed here. Shingles should not be jammed tightly together. All attics should be properly ventilated. Note: It is not necessary to remove tape on back of shingle.

● DECK PREPARATION

Roof decks should be dry, well-seasoned 1" x 6" boards or exterior grade plywood minimum 3/8" thick and conform to the specifications of the American Plywood Association or 7/16" oriented strandboard, or 7/16" chipboard.

● UNDERLAYMENT

Apply underlayment (Non-Perforated No. 15 or 30 asphalt saturated felt). Cover drip edge at eaves only. For low slope (2/12 up to 4/12), completely cover the deck with two plies of underlayment overlapping a minimum of 19". Begin by fastening a 19" wide strip of underlayment placed along the eaves. Place a full 36" wide sheet over the starter, horizontally placed along the eaves and completely overlapping the starter strip.

EAVE FLASHING FOR ICE DAMS (ASK A ROOFING CONTRACTOR, REFER TO ARMA MANUAL OR CHECK LOCAL CODES)

For standard slope (4/12 to less than 21/12), use coated roll roofing of no less than 50 pounds over the felt underlayment extending from the eave edge to a point at least 24" beyond the inside wall of the living space below or one layer of a self-adhered eave and flashing membrane. For low slope (2/12 up to 4/12), use a continuous layer of asphalt plastic cement between the two plies of underlayment from the eave edge up roof to a point at least 24" beyond the inside wall of the living space below or one layer of a self-adhered eave and flashing membrane.

Consult the Elk Field Service Department for application specifications over other decks and other slopes.

● STARTER SHINGLE COURSE

USE AN ELK STARTER STRIP OR A STRIP SHINGLE INVERTED WITH THE HEADLAP APPLIED AT THE EAVE EDGE. With at least 4" trimmed from the end of the first shingle, start at the rake edge overhanging the eave 1/2" to 3/4". Fasten 2" from the lower edge and 1" from each side. Shingles may be applied with a course alignment of 45° on the roof.

● FIRST COURSE

Start at rake and continue course with full shingles laid flush with the starter course.

● SECOND COURSE

Start at the rake with the shingle having 10" trimmed off and continue across roof with full shingles.

● THIRD COURSE

Start at the rake with the shingle having 20" trimmed off and continue across roof with full shingles.

● FOURTH COURSE

Start at the rake and continue with full shingles across roof.

FIFTH AND SUCCEEDING COURSES.

Repeat application as shown for second, third, and fourth courses. Do not rack shingles straight up the roof.

● VALLEY CONSTRUCTION

Open, woven and closed cut valleys are acceptable when applied by Asphalt Roofing Manufacturing Association (ARMA) recommended procedures. For metal valleys, use 36" wide vertical underlayment prior to applying 18" metal flashing (secure edge with nails). No nails are to be within 6" of valley center.

● RIDGE CONSTRUCTION

For ridge construction use Class "A" Seal-A-Ridge® with formula FLX™ (See ridge package for installation instructions.)

FASTENERS

While nailing is the preferred method for Elk shingles, Elk will accept fastening methods according to the following instructions. Always nail or staple through the fastener line or on products without fastener lines, nail or staple between and in line with sealant dots.

NAILS: Corrosive resistant, 3/8" head, minimum 12-gauge roofing nails. Elk recommends 1-1/4" for new roofs and 1-1/2" for re-roofs. In cases where you are applying shingles to a roof that has an exposed overhang, for new roofs only, 3/4" ring shank nails are allowed to be used from the eave's edge to a point up the roof that is past the outside wall line. 1" ring shank nails allowed for re-roof.

STAPLES: Corrosive resistant, 16-gauge minimum, crown width minimum of 15/16". Note: An improperly adjusted staple gun can result in raised staples that can cause a fish-mouthed appearance and can prevent sealing.


Fasteners should be long enough to obtain 3/4" deck penetration or penetration through deck, whichever is less.

MANSARD APPLICATIONS

Correct fastening is critical to the performance of the roof. For slopes exceeding 60° (or 21/12) use six fasteners per shingle. Locate fasteners in the fastener area 1" from each side edge with the remaining four fasteners equally spaced along the length of the double thickness (laminated) area. Only fastening methods according to the above instructions are acceptable.


LIMITED WIND WARRANTY

- For a Limited Wind Warranty, all Prestique and Raised Profile™ shingles must be applied with 4 properly placed fasteners, or in the case of mansard applications, 6 properly placed fasteners per shingle.
- For a Limited Wind Warranty up to 110 MPH for Prestique Gallery Collection or Prestique Plus and 90 MPH for Prestique 1, shingles must be applied with 6 properly placed NAILS per shingle. SHINGLES APPLIED WITH STAPLES WILL NOT QUALIFY FOR THIS ENHANCED LIMITED WIND WARRANTY. Also, Elk Starter Strip shingles must be applied at the eaves and rake edges to qualify Prestique Plus, Prestique Gallery Collection and Prestique 1 shingles for this enhanced Limited Wind Warranty. Under no circumstances should the Elk Shingles or the Elk Starter Strip overhang the eaves or rake edge more than 3/4" of an inch.



HELP STOP BLOW-OFFS AND CALL-BACKS

A minimum of four fasteners must be driven into the DOUBLE THICKNESS (laminated) area of the shingle. Nails or staples must be placed along - and through - the "fastener line" or on products without fastener lines, nail or staple between and in line with sealant dots. CAUTION: Do not use fastener line for shingle alignment.



Refer to local codes which in some areas may require specific application techniques beyond those Elk has specified. All Prestique and Raised Profile shingles have a UL® Wind Resistance Rating when applied in accordance with these instructions using nails or staples on re-roofs as well as new construction.

CAUTION TO WHOLESALE: Careless and improper storage or handling can harm fiberglass shingles. Keep these shingles completely covered, dry, reasonably cool, and protected from the weather. Do not store near various sources of heat. Do not store in direct sunlight until applied. DO NOT DOUBLE STACK. Systematically rotate all stock so that the material that has been stored the longest will be the first to be moved out.

© 2002 Elk Corporation of Dallas.

All trademarks, ® are registered trademarks of Elk Corporation of Dallas, an ELCOR company. Raised Profile, RidgeCrest, Gallery Collection and FLX are trademarks pending registration of Elk Corporation of Dallas. UL is a registered trademark of Underwriters Laboratories, Inc.

ELK
www.elkcorp.com



Underwriters Laboratories Inc. ®

333 Piquette Road
Northbrook, Illinois 60062-7000
United States Country Code (1)
(847) 272-4800
FAX No. (847) 272-8129
<http://www.ul.com>

March 4, 2002

GAF Materials Corporation
Mr Randall Ziegler
1361 Alps Road
Wayne, NJ 07470

Our Reference: R21

Subject: UL Listed products

Dear Mr Ziegler:


This is in response to your request to identify some of the products that are currently Listed with Underwriters Laboratories relating to various Standards. Following are those products:

Royal Sovereign®
Marquis®/Marquis® WeatherMax®
SLATELINE®
Grand canyon™
Grand Sequoia®
Country Mansion™
Country Estates™
Timberline 30™
Timberline Select™ 40
Timberline Ultra™
Sentinel®


The above products have been tested to ASTM D3462, Class A UL790/ASTM E108 and UL 997/ ASTM D3161 (secured with 4 nails) with velocities up to 110 mph and have successfully met those test criteria.

If you have any questions please feel free to contact the writer.

Very truly yours,


Roger Anderson (Ext. 43283)
Senior Engineering Associate
Conformity Assessment Services- 3011E-NBK

Reviewed by,



Douglas C. Miller (Ext. 43262)
Engineering Group Leader
Conformity Assessment Services- 3011E-NBK



MARQUIS[®] **WeatherMax[®]** SHINGLES **ROYAL SOVEREIGN[®]** SHINGLES **SENTINEL[®]** SHINGLES

APPLICATION INSTRUCTIONS

Note: These shingles must be nailed a nominal 5 5/8" (143mm) from bottom of shingles, not in or above self seal, as shown. Nails should remain unexposed.



GENERAL INSTRUCTIONS


- **ROOF DECKS:** For use on new or reroofing work over well-seasoned, supported wood deck, tightly-constructed with maximum 6" (152mm) wide lumber, having adequate nail-holding capacity and smooth surface. Plywood decking as recommended by The Engineered Wood Assn. is acceptable. Plywood decks for Class A installations must be 3/8" (10mm) thick or greater with underlayments as noted below. Shingles must not be fastened directly to insulation or insulated deck unless authorized in writing by GAF Materials Corporation. Roof decks and existing surfacing material must be dry prior to application of shingles.
- **UNDERLAYMENT:** Underlayment is required on new construction and required for reroofing when old roof is removed from the deck. Use only "breather type" material like GAF Materials Corporation Shingle-Mate[®] Underlayment or equivalent. Underlayments must be installed flat, without wrinkles.
- **FASTENERS:** Use of nails is recommended. (Staple specifications and application instructions are available from GAF Materials Corporation, Contractor Services Dept., 1361 Alps Road, Wayne, NJ 07470.) Use only zinc coated steel or aluminum, 10-12 gauge, barbed, deformed or smooth shank roofing nails with heads 3/8" (10mm) to 7/16" (12mm) in diameter. Fasteners should be long enough to penetrate at least 3/4" (19mm) into wood decks or just through the plywood decks. Fasteners must be driven flush with the surface of the shingle. Over driving will damage the shingle. Raised fasteners will interfere with the sealing of the shingles. For normal installation, four fasteners must be installed per shingle, a nominal 5 5/8" (143mm) up from the bottom of the shingle. Fasteners must be installed approximately 1" (25mm) from each side.
- **WIND RESISTANT:** These shingles have a special thermal sealant that firmly bonds the shingles together after application when exposed to sun and warm temperatures. Shingles installed in Fall or Winter may not seal until the following Spring. If shingles are damaged by winds before sealing or are not exposed to adequate surface temperatures, or if the self-sealant gets dirty, the shingles may never seal. Failure to seal under these circumstances results from the nature of self-sealing shingles and is not a manufacturing defect. To insure immediate sealing,

- apply 2 quarter-sized dabs of shingle tab adhesive on the back of each tab, approximately 1" (25mm) from end and 1" (25mm) up from bottom of each tab corner. The shingle must be pressed firmly into the adhesive.
- NOTE:** Application of excess tab adhesive can cause blistering of the shingle.
- For maximum wind resistance along rakes, cement shingles to underlayment and each other in a 4" (102mm) width of asphalt plastic roof cement.
- NOTE:** The film strips on the back of each shingle are to prevent sticking together of the shingles while in the bundle. Their removal is NOT required during application.
- **CANADIAN COLD WEATHER APPLICATIONS:** CSA A123.5-M90 mandates that shingles applied between September 1 and April 30 shall be adhered with a compatible field-applied adhesive. See Wind Resistant for GAF Materials Corporation's recommendations for the application of that adhesive.
- **MANSARD AND STEEP SLOPE APPLICATIONS:** For roof slopes greater than 21° (1750mm/m) per foot (do NOT use on vertical side walls), shingle sealing must be enhanced by hand sealing. After fastening the shingle in place, apply 2 quarter-sized dabs of shingle tab adhesive as indicated in Wind Resistant above. The shingle must be pressed firmly into the adhesive.
- **EXPOSURE:** 5" (127mm)
- **THROUGH VENTILATION:** All roof structures must be provided with through ventilation to prevent entrapment of moisture laden air behind roof sheathing. Ventilation provisions must at least meet or exceed current F.H.A., H.U.D. or local code minimum requirements.
- **NON-CORRODING METAL DRIP EDGES:** Recommended along rake and eave edges on all decks, especially plywood decks.
- **ASPHALT PLASTIC CEMENT:** For use as shingle tab adhesive. Must conform to ASTM D4586 Type I or II.

1 Underlayment: Standard Slope—4/12 (333mm/m) or more


Application of underlayment: Cover deck with one layer of underlayment installed without wrinkles. Use only enough nails to hold underlayment in place until covered by shingles.

Application of eave flashing: Install eave flashing such as GAF Materials Corporation Weather Watch[®] or StormGuard[®] Leak Barrier in localities where leaks may be caused by water backing up behind ice or debris dams. Eave flashing must overhang the roof edge by 3/8" (10mm) and extend 24" (610mm) beyond the inside wall line.




1a Underlayment: Low Slope 2/12-4/12 (167mm-333mm/m)

Application of underlayment and eave flashing: Completely cover the deck with two layers of underlayment as shown. Use only enough nails to hold underlayment in place until covered by shingles. Use blind nailing for eave flashings. At eaves and where ice dams can be expected, use one layer of GAF Materials Corporation Weather Watch[®] or StormGuard[®] Leak Barrier. Eave flashing must overhang the roof edge by 3/8" (10mm) and extend 24" (610mm) beyond the inside wall line. Where ice dams or debris dams are not expected, install 2 plies of Shingle-Mate[®] underlayment.




2 Starter Course

Use of any GAF MC 3-tab Shingle is recommended. Apply as shown.



3 First Course


Start and continue with full shingles laid flush with the starter course. Shingles may be laid from left to right or right to left. DO NOT lay shingles straight up the roof since this procedure can cause an incorrect color blend on the roof and may damage the shingles.




4 Second Course

Start and continue second course and all even numbered courses as shown. Position the shingle on the top of the cutouts of the underlying shingle so that there will be 5" (127mm) of each shingle exposed. Strike a chalk line about every 6 courses to check parallel alignment with eaves. Factory applied self-sealing dots on lower courses are designed to seal down the shingle tabs in an upper course.


NOTE: Shingles may be laid from either left or right hand side. Start at either rake edge with shingles having 6" (152mm) trimmed from rake.




6 Wall Flashing (Sloped Roof to Vertical Wall)



8 Valley Construction - Closed or Woven Valley




10 Valley Construction—Closed Cut




5 Hip and Ridge


Use GAF hip & ridge shingles, or cut hip & ridge shingles from these full shingles, and apply as shown. Position laps away from prevailing wind direction.



7 Chimney Flashing



9 Valley Construction—Open Cut



Precautionary Notes

These shingles are fiberglass, self-sealing asphalt shingles. Because of the natural characteristics of the high quality waterproofing material used, these shingles will be stiff in cold weather and flexible in hot weather.

1. Bundles should not be dropped on edge nor should attempt be made to separate shingles by "breaking" over ridge or other bundles.
2. Handle carefully. Shingles can easily be broken in cold weather or their edges damaged in hot weather.
3. All exposed materials must be of Class A type.
4. Storage should be in a covered, ventilated area—maximum temperature 110°F (43°C.) Store on flat surface and use weight equalization boards if pallets are to be double stacked. Shingles must be protected from weather when stored at job site. Do not store near steam pipes, radiators, etc., or in sunlight. All rolled product must be stored on ends.
5. If shingles are to be applied during PROLONGED COLD periods or in areas where airborne dust or sand can be expected before sealing occurs, the shingles MUST be hand sealed. See Wind Resistant instructions.

Re-Roofing

If old asphalt shingles are to remain in place, nail down or cut away all loose, curled or lifted shingles; replace with new; and just before applying the new roofing, sweep the surface clean of all loose debris. Since any irregularities may show through the new shingles, be sure the underlying shingles provide a smooth surface. Fasteners must be of sufficient length to penetrate the wood deck at least 3/4" (19mm) or just through plywood. Follow other above instructions for application. Note: Shingles can be applied over wood shingles when precautions have been taken to provide an acceptable smooth surface. This includes cutting back old shingles at eaves and rakes and installing new wood edging strips as needed. Make surface smooth and use beveled wood strips if necessary. Install #30 underlayment to maintain Class A rating.

This product is sold with an express LIMITED WARRANTY only. A copy of the LIMITED WARRANTY stating its terms and restrictions is printed on the product wrapper or may be obtained from the distributor of this product or directly from GAF Materials Corporation. Any deviation from printed instructions shall be the responsibility of applicator and/or specifier.



TIMBERLINE[®]

SHINGLES

TIMBERLINE[®]

SHINGLES


TIMBERLINE[®]

SHINGLES

APPLICATION INSTRUCTIONS

Timberline[®] Series shingles come in either 36" (914mm) or 36-15/16" (938mm) lengths, depending on shingle brand. Application instructions apply to both.

These shingles must be nailed a nominal 5-5/8" (143mm) from bottom of shingles, as shown, to allow for penetration through the double ply area just above the tabs. Nails should remain unexposed.



GENERAL INSTRUCTIONS

• **ROOF DECKS:** For use on new or reroofing work over well-seasoned, supported wood deck, tightly-constructed with maximum 6" (152mm) wide lumber, having adequate nail-holding capacity and smooth surface. Plywood decking as recommended by The Engineered Wood Assn. is acceptable. Plywood decks for Class A installations must be 3/8" (10mm) thick or greater with underlayment as noted below. Shingles must not be fastened directly to insulation or insulated deck unless authorized in writing by GAF Materials Corporation. Roof decks and existing surfacing material must be dry prior to application of shingles.

• **UNDERLAYMENT:** Underlayment beneath shingles has many benefits, including preventing wind driven rain from reaching the interior of the building and preventing sap in some wood decking from reacting with asphalt shingles. Underlayment is also required by many code bodies. Consult your local building department for its requirements. Where an underlayment is to be installed, a breather-type underlayment such as GAFMC's Shingle-Mate[®] underlayment is recommended. Underlayment must be installed flat, without wrinkles.

• **FASTENERS:** Use of nails is recommended. (Staple specifications and application instructions are available from GAF Materials Corporation, Contractor Services Dept., 1361 Alps Road, Wayne, NJ 07470.) Use only zinc coated steel or aluminum, 10-12 gauge, barbed, deformed or smooth shank roofing nails with heads 3/8" (10mm) to 7/16" (12mm) in diameter. Fasteners should be long enough to penetrate at least 3/4" (19mm) into wood decks or just through the plywood decks. Fasteners must be driven flush with the surface of the shingle. Over driving will damage the shingle. Raised fasteners will interfere with the sealing of the shingles. For normal installation, four fasteners must be installed per shingle, a nominal 5-5/8" (143mm) up from the bottom of the shingle, to penetrate both layers of the shingle. Fasteners must be installed approximately 1" - 1 1/2" (25-38mm) and 11-1/2"-12-1/2" (292-318mm) from each side.

• **WIND RESISTANT:** These shingles have a special thermal sealant that firmly bonds the shingles together after application when exposed to sun and warm temperatures. Shingles installed in Fall or Winter may not seal until the following Spring. If shingles are damaged by winds

before sealing or are not exposed to adequate surface temperatures, or if the self-sealant gets dirty, the shingles may never seal. Failure to seal under these circumstances results from the nature of self-sealing shingles and is not a manufacturing defect. To insure immediate sealing, apply 4 quarter-sized dabs of shingle tab adhesive on the back of the shingle 1" (25mm) and 13" (330mm) in from each side and 1" (25mm) up from bottom of the shingle. The shingle must be pressed firmly into the adhesive.

NOTE: Application of excess tab adhesive can cause blistering of the shingle.

For maximum wind resistance along rakes, cement shingles to underlayment and each other in a 4" (102mm) width of asphalt plastic roof cement.

NOTE: The film strips on the back of each shingle are to prevent sticking together of the shingles while in the bundle. Their removal is NOT required during application.

• **CANADIAN COLD WEATHER APPLICATIONS:** CSA 123.5-M90 mandates that shingles applied between September 1 and April 30 shall be adhered with a compatible field-applied adhesive. See Wind Resistant for GAF Materials Corporation's recommendations for the application of that adhesive.

• **MANSARD AND STEEP SLOPE APPLICATIONS:** For roof slopes greater than 21° (1750mm/m) per foot (do NOT use on vertical side walls), shingle sealing must be enhanced by hand sealing. After fastening the shingle in place, apply 4 quarter-sized dabs of shingle tab adhesive as indicated in Wind Resistant above. The shingle must be pressed firmly into the adhesive.

• **EXPOSURE:** 5" (127mm)

• **THROUGH VENTILATION:** All roof structures must be provided with through ventilation to prevent entrapment of moisture laden air behind roof sheathing. Ventilation provisions must at least meet or exceed current F.H.A., H.U.D. or local code minimum requirements.


• **NON-CORRODING METAL DRIP EDGES:** Recommended along rake and eave edges on all decks, especially plywood decks.

• **ASPHALT PLASTIC CEMENT:** For use as shingle tab adhesive. Must conform to ASTM D4586 Type I or II.

1 Underlayment: Standard Slope-4/12 (333mm/m) or more


Application of underlayment: Cover deck with one layer of underlayment installed without wrinkles. Use only enough nails to hold underlayment in place until covered by shingles.

Application of eave flashing: Install eave flashing such as GAF Materials Corporation Weather Watch[®] or StormGuard[®] Leak Barrier in localities where leaks may be caused by water backing up behind ice or debris dams. Eave flashing must overhang the roof edge by 3/8" (10mm) and extend 24" (610mm) beyond the inside wall line.




1a Underlayment: Low Slope 2/12-4/12 (167mm-333mm/m)

Application of underlayment and eave flashing: Completely cover the deck with two layers of underlayment as shown. Use only enough nails to hold underlayment in place until covered by shingles. Use blind nailing for eave flashings. At eaves and where ice dams can be expected, use one layer of GAF Materials Corporation Weather Watch[®] or StormGuard[®] Leak Barrier. Eave flashing must overhang the roof edge by 3/8" (10mm) and extend 24" (610mm) beyond the inside wall line. Where ice dams or debris dams are not expected, install 2 plies of Shingle-Mate[®] underlayment.




2 Starter Course

Apply as shown.




3 First Course

Start and continue with full shingles laid flush with the starter course. Shingles may be laid from left to right or right to left. DO NOT lay shingles straight up the roof since this procedure can cause an incorrect color blend on the roof and may damage the shingles.




4 Second Course

Start and continue second course as shown. Trim 6" (152mm) from the end of the shingle. Position the shingles in the second and subsequent courses flush with the tops of the wide cutouts. This results in a 5" (127mm) exposure. Continue with full width shingles across the roof. Strike a chalk line about every 6 courses to check parallel alignment with eaves. NOTE: Shingles may be laid from either left or right hand side. Start at either rake edge with shingles having 6" (152mm) trimmed from rake.




6 Fourth Course and Remaining Courses


Trim 17" (432mm) from first shingle in the course, then continue with full shingles across the roof. Fifth and subsequent courses repeat full shingle instructions from Step 3.



8 Wall Flashing (Sloped Roof to Vertical Wall)




10 Valley Construction-Closed Cut




5 Third Course

Trim 11" (279mm) from the first shingle in the course then continue with full shingles across the roof.




7 Hip and Ridge


For single layer application, use hip and ridge shingles and apply as shown. To enhance appearance, use GAF TIMBERTEX® or a double layer application of Universal Hip & Ridge. (One bundle of TIMBERTEX® Hip & Ridge covers 20 lineal ft.-6.1 meters.) For double application, start with triple thickness of precut Hip & Ridge shingles and continue remainder with double thickness. Fasten in same manner as single application shown. Apply laps away from prevailing wind direction.



9 Chimney Flashing



11 Valley Construction-Open



Precautionary Notes

Timberline® Series shingles are fiberglass, self-sealing asphalt shingles. Because of the natural characteristics of the high quality waterproofing material used, these shingles will be stiff in cold weather and flexible in hot weather.

1. Bundles should not be dropped on edge nor should attempt be made to separate shingles by "breaking" over ridge or other bundles.
2. Handle carefully. Shingles can easily be broken in cold weather or their edges damaged in hot weather.
3. All exposed materials must be of Class A type.
4. Storage should be in a covered, ventilated area-maximum temperature 110°F (43°C.) Store on flat surface and use weight equalization boards if pallets are to be double stacked. Shingles must be protected from weather when stored at job site. Do not store near steam pipes, radiators, etc., or in sunlight. All rolled product must be stored on ends.
5. If shingles are to be applied during PROLONGED COLD periods or in areas where airborne dust or sand can be expected before sealing occurs, the shingles MUST be hand sealed. See Wind Resistant instructions.

Re-Roofing

If old asphalt shingles are to remain in place, nail down or cut away all loose, curled or lifted shingles; replace with new; and just before applying the new roofing, sweep the surface clean of all loose debris. Since any irregularities may show through the new shingles, be sure the underlying shingles provide a smooth surface. Fasteners must be of sufficient length to penetrate the wood deck at least 3/4" (19mm) or just through plywood. Follow other above instructions for application.

Note: Shingles can be applied over wood shingles when precautions have been taken to provide an acceptable smooth surface. This includes cutting back old shingles at eaves and rakes and installing new wood edging strips as needed. Make surface smooth and use beveled wood strips if necessary. Install #30 underlayment to maintain Class A rating.

This product is sold with an express LIMITED WARRANTY only. A copy of the LIMITED WARRANTY stating its terms and restrictions is printed on the product wrapper or may be obtained from the distributor of this product or directly from GAF Materials Corporation. Any deviation from printed instructions shall be the responsibility of applicator and/or specifier.


CERTIFIED TESTING LABORATORIES

Architectural Division • 7252 Narcoossee Rd. • Orlando, FL 32822

(407) 384-7744 • Fax (407) 384-7751

Web Site: www.ctilarch.com

E-mail: ctilarch.com



Report Number: CTLA-991W-1-AWT

Report Date: February 18, 2003

STRUCTURAL PERFORMANCE TEST REPORT

Client: ACTION WINDOOR TECHNOLOGY INC
1312 W. CROSBY ROAD
CARROLLTON, TX 75006

Product Type and Series: AWT Series 3950 Vinyl Fin Frame Single Hung Window with Reinforced Sash Top Rail, Stiles & Meeting Rail H-R40 (36" x 72")

Test Specifications: AAMA/NWWDA 101/LS-2-97 "Voluntary Specifications for Aluminum, Vinyl (PVC) and Wood Windows and Glass Doors"

Frame: Vinyl Fin frame measured 35.50" wide x 71.50" high overall. Mitered corner weld construction. Fixed meeting rail secured to each frame jamb with one (1) #8 x 2" PH., PH. screw.

Ventilator: Operable sash measured 33.375" wide x 35.25" high overall. Mitered corner weld construction. Clear lite measured 31.5625" high x 33.5625" high. Fixed lite measured 32.50" wide x 33.4375" high.

Weather Stripping: One (1) strip of woolpile .220" high with integral plastic fin frame sill. One (1) strip of woolpile .250" high with integral plastic fin sash top rail exterior. One (1) strip of woolpile .250" high each sash stile exterior leg. One (1) strip of woolpile .250" high with integral plastic fin each sash stile interior leg. One (1) strip of foam filled bulb weatherstrip sash bottom rail.

Hardware & Location: Two (2) metallic sweep locks located on sash top rail approx 8" from each end of rail. Two (2) metallic keepers located on fixed meeting rail. One (1) tilt latch at each end of sash top rail. One (1) block and tackle at each frame jamb. One (1) pivot bar at each end of sash bottom rail.

Glazing: 5/8" insulated annealed glass consisting of .125" glass .375" air space with swiggle .125" glass. Sash exterior glazed. Fixed lite interior glazed adhesive foam strip backbedding and vinyl snap in glazing bead.

Sealant: A silicone type sealant was used on sill and to seal specimen to test buck.

Weep System: Weep notch measuring 2.25" x leg height located each end of sill weeping to the exterior

Muntins: N/A

Reinforcement: Fixed meeting rail has one (1) piece of extruded aluminum reinforcement measuring .662" wide x .755" high x .099" thick x full length. Top rail, and sash stiles has one (1) piece of extruded aluminum reinforcement measuring .590" wide x .995" high x .115" thick x full length.

Additional Description: N/A

Screen: Roll formed aluminum frame, fiberglass mesh with vinyl spline. Two (2) metallic retainer clips and two (2) metallic plungers. Corners secured with plastic corner keys

Installation: Twenty-six (26) 1.75" roofing nails were used to secure the specimen to the wood test buck. Five (5) were located in head and sill measuring 4", 13", 21", 29", and 33" from left jamb. Eight (8) were located in each jamb measuring 4.50", 14.25", 24", 32.75", 42", 57.25", 60.50" and 70" from sill.

Surface Finish: White Vinyl

Comment: Nominal 2 mil polyethylene film was used to seal against air leakage during structural loads. The film was used in a manner that did not influence the test results

Performance Test Results

<u>Paragraph No</u>	<u>Title of Test</u>	<u>Method</u>	<u>Measured</u>	<u>Allowed</u>
2.1.2	Air Infiltration @1.37 psf	ASTM E283-91	.18 cfm/ft ²	.34 cfm/ft ²
The tested specimen meets or exceeds the performance levels specified in AAMA/NWDA 101/F.S.2-97. Results recorded in two (2) decimals at the clients request. Unit tested with shims installed under cam locks.				
2.1.3	Water Resistance @ 5.0 gph/ft ²	ASTM E547-93 Four (4) five (5) minute cycles	No Entry	No Entry
	WTP= 6.75 psf	ASTM E331-93 Fifteen (15) minute duration	No Entry	No Entry
	Unit tested with insect screen.			
2.1.3	Water Resistance @ 5.0 gph/ft ²	ASTM E547-93 Four (4) five (5) minute cycles	No Entry	No Entry
	WTP= 6 psf	ASTM E331-93 Fifteen (15) minute duration	No Entry	No Entry
	Unit tested without insect screen.			
2.1.4.2	Uniform Load Structural Permanent Deformation @ 60 psf positive @ 60 psf negative	ASTM E330-90 Ten (10) second load	.015" .005"	.134" .134"
2.1.8	Forced Entry Resistance	AAMA 1302.5-76		
	Test A		0"	1/2"
	Test B		0"	1/2"
	Test C		0"	1/2"
	Test D, E and F		0"	1/2"
	Test G		0"	1/2"

Performance Test Results (continued)

<u>Paragraph No</u>	<u>Title of Test</u>	<u>Method</u>	<u>Measured</u>	<u>Allowed</u>
2.2.2.5.1	Operating Force Sash	AAMA/NWDA 101/1.S.2-97	18 lbs.	30 lbs.
2.2.2.5.2	Deglazing Top Rail 70 lbs Bottom Rail 70 lbs. Left Side 50 lbs. Right Side 50 lbs.	ASTM E987-88	.039" = 7.8%<100% .038" = 7.6%<100% .050" = 10%<100% .035" = 7.0%<100%	
2.1.7	Welded Corner Test	AAMA/NWDA 101/ IS2-97	Passed	

Test Date November 21, 2002


Test Completion Date: November 21, 2002

Remarks: Detailed drawings were available for laboratory records and comparison to the test specimen at the time of this report. A copy of this report along with representative sections of the test specimen will be retained by CTL for a period of four (4) years. The results obtained apply only to the specimen tested.

This test report does not constitute certification of this product, but only that the above test results were obtained using the designated test methods and they indicate compliance with the performance requirements (paragraphs as listed) of the above referenced specifications.

Certified Testing Laboratories assumes that all information provided by the client is accurate and that the physical and chemical properties of the components are as stated by the manufacturer.

Certified Testing Laboratories, Inc.



James W. Blakely
Vice President
Architectural Division

cc: Action Window Technology Inc. (3)
File (1)

Report Number: ETC-04-034-14644.0
Test Start Date: 04/10/03
Test Finish Date: 03/16/04
Report Date: 03/18/04
Expiration Date: 03/18/08

Fenestration Structural Test Report
Rendered To:

Vinyl Building Products, Inc.
One Raritan Road
Oakland, NJ 07436

Series/Model
2900 Horizontal Slider (OX)

Description: The product tested was a vinyl Horizontal Sliding window. The test specimen was glazed with 5/8-inch thick insulating glass units constructed with double strength annealed glass. The frame size was 69 inches wide by 48 inches high by 2-3/4 inches deep. See Appendix A.

Test Specification: ANSI/AAMA/NWDA 101/1.S.2

Summary of Results

Overall Design Pressure	35.0 psf
Air Leakage Rate	0.18 scfm/ft ²
Maximum Water Pressure Achieved	5.25 psf
Maximum Structural Pressure Achieved	60.0 psf
Forced Entry Resistance - (ASTM)	Grade 10

Product Designation **H-R35 69 x 48**

TEST REPORT

ETC Laboratories

Specifications: The test specimen was evaluated in accordance with ANSI/AAMA/NWDA 101/I.S.2 "Voluntary Specification for Aluminum, Vinyl and Wood Windows and Glass Doors". Sections 1, 2 and 4 only. All performance specifications in this standard shall be met for full compliance to the standard and for product certification, labeling or represented as conforming to this standard.

Referenced Test Reports: NONE

Note - The test data in any section below with an "KTR" comment have not been obtained from this specimen but from the Referenced Test Report with a specimen of the same or larger size and identical construction.

Design Pressure (DP): The product tested herein has been first evaluated to the Gateway pressure in the referenced specification for the performance class rating achieved.

Gateway Performance Tests

<u>Specification Paragraph</u>	<u>Title of Test</u>	<u>Results</u>	<u>Allowed</u>
2.1.2	<u>Air Infiltration - ASTM E283</u> Test Pressure - 1.57 psf The tested specimen exceeds the performance levels specified in ANSI/AAMA/NWDA 101/I.S.2 for air infiltration.	0.18 scfm/ft ²	0.30 scfm/ft ²
2.1.3	<u>Water Resistance - ASTM E547</u> 5 gal/hr-ft ² - 4 Test cycles - 24 Minutes Design Pressure - 15.0 psf Test Pressure - 2.86 psf With and Without Screen	Pass	No leakage
2.1.4.2	<u>Uniform Structural Load - ASTM E330</u> Design Pressure - 15.0 psf Test Pressure Positive Load - 22.5 psf (150% x DP) Negative Load - 22.5 psf (150% x DP) Note: Measurement taken after load from center of the meeting stile	0.033 in. 0.020 in.	0.177 in. 0.177 in.
2.1.7	<u>Corner Weld</u> Frame - 4 Corners Sashes - 4 Corners	Pass Pass	< 100% < 100%
2.1.8	<u>Forced Entry Resistance - ASTM F588</u> Lock/Tool Manipulation Tests A1 through A7 Lock/Tool Manipulation	Pass Pass Pass	No Entry No Entry No Entry
2.2.1.6.1	<u>Operating Force - No Standardized Method</u> Right Sash - Open/Close	18/18 lbf	20 lbf
2.2.1.6.2	<u>Deglazing - ASTM E987</u> Right Sash: Left Stile - 70 lbf Right Stile - 70 lbf Top Rail - 50 lbf Bottom Rail - 50 lbf	0.0% 0.0% 0.0% 0.0%	<100% <100% <100% <100%

Optional Performance Tests

The manufacturer specified herein has successfully achieved all the required criteria in Section 2 of the referenced specification for the Gateway size of the achieved Performance Rating and has further successfully tested the product to higher performance levels as indicated below.

Design Pressure (DP): The product tested herein has been additionally evaluated to the Design Pressure referenced below.

<u>Specification Paragraph</u>	<u>Title of Test</u>	<u>Results</u>	<u>Allowed</u>
4.3	<u>Water Resistance - ASTM E547</u> 5 gal/hr-ft ² -- 4 Test cycles -- 24 Minutes Design Pressure - 35.0 psf Test Pressure - 5.25 psf (15% x DP) With and Without Screen	Pass	No Leakage
4.4	<u>Uniform Structural Load - ASTM E330</u> Design Pressure - 40.0 psf Test Pressure Positive Load - 60.0 psf (150% x DP) Negative Load - 60.0 psf (150% x DP) Note: Measurement taken after load from center of meeting stile	0.069 in. 0.066 in.	0.177 in. 0.177 in.

Conditions, Terms, and General Notes Regarding These Tests

The product tested Has Been compared to the detailed drawings, bill of materials and fabrication information supplied by the client so named herein. Our analysis, which includes dimensional and component description comparisons, indicate the tested product and engineering information supplied by the client "Are Equivalent". See Appendix A. The report and representative samples will be retained for four years from the date of initial test.

These test results were obtained by employing all requirements of the designated test methods with no deviations. The test results and specimen supplied for testing are in compliance with the referenced specifications.

The test results are specific to the product tested by this laboratory and of the sample supplied by the client named herein, and they relate to no other product either manufactured by the client, a Fabricator of the client or of installed field performance.

This report does not constitute an AAMA or NWWDA certified product under the certification programs of these organizations. The program administrator of these programs and organizations may only grant product certification.


ETC Laboratories makes no opinions or endorsements regarding this product and its performance. This report may not be reproduced or quoted in partial form without the expressed written approval of ETC Laboratories.


No conclusions of any kind regarding the adequacy of the glass in the test specimen may be drawn from the test. Procedure "A" in ASTM E330 was used for this test.

ETC Laboratories letters, reports, its name or insignia or mark are for the exclusive use of the client so named herein and any other use is strictly prohibited. The report, letters and the name of ETC Laboratories, its seal or mark shall not be used in any circumstance to the general public or in any advertising.

Limitation of Liability: Due diligence was used in rendering this professional opinion. By acceptance of this report, this client agrees to hold harmless and indemnify ETC Laboratories, its employees and offices and owners against all claims and demands of any kind whatsoever, which arise out of or in any manner connected with the performance of work referred to herein.

FOR ETC LABORATORIES


Mark Sennett
AWS Supervisor



Arthur Murray, VP
Manager, Wind Engineering Laboratory

TEST REPORT

ETC Laboratories

ALTERNATE ROLLER COMPASS
ATTACHED W/ (2) 1/4" x 1/2"
BELT & NUT PER BRACKET


16 GA. GALV. ROLLER
ATTACHED W/ (2) 1/4" x 1/2"
BELT & NUT PER BRACKET




Y ZONE STRUT ATTACHED
W/ (2) 1/4" x 3/4"
NUT HEAD SCREWS AT
EACH CENTER STILE




1/4" DIA. BRACKET
CENTER HOLE ATTACHED
W/ (2) 1/4" x 3/4"
NUT HEAD SCREWS



STILE STRUTS CO.
LOCATED IN HOLE, HELD IN
BY THE STRUT ONLY



TYPICAL STILE STRUTTED
N.T.S.




INSIDE ELEVATION
N.T.S.



TYPICAL BRACKET END HINGE
N.T.S.



TYPICAL BRACKET CENTER
N.T.S.



TYPICAL BRACKET CENTER
N.T.S.

WOOD JAMB ATTACHMENT TO STRUCTURE
N.T.S.

1. ALL THE JAMB SHALL BE SUBMITTED TO THE ARCHITECT, OWNER, AND ENGINEER FOR REVIEW AND APPROVAL PRIOR TO CONSTRUCTION.

2. THE JAMB SHALL BE ATTACHED TO THE STRUCTURE BY MEANS OF AN ANCHOR BOLT OR WELDING.

3. THE JAMB SHALL BE ATTACHED TO THE STRUCTURE BY MEANS OF AN ANCHOR BOLT OR WELDING.


4. THE JAMB SHALL BE ATTACHED TO THE STRUCTURE BY MEANS OF AN ANCHOR BOLT OR WELDING.

5. THE JAMB SHALL BE ATTACHED TO THE STRUCTURE BY MEANS OF AN ANCHOR BOLT OR WELDING.


GLAZING OPTION CROSS SECTION

GLAZING NOT AVAILABLE IN THIS MODEL DESIGN OPTION

TEST 2. RC-6000-100-15 OR GREATER IS THE MINIMUM GLAZING IN THE
SECTION. UP TO 100% OF THE SECTION MAY BE GLAZED IN (1) ONE SECTION
OR OTHER THE MODEL, AND ON AND DOORS CONSTRUCTED FOR THIS MODEL.




SECTION B-B



MAXIMUM COMPARTMENT FOR 60" UP TO 64" TALL DOORS
N.T.S.

SECTION A-A (SIDE VIEW)
N.T.S.



SECTION A-A (SIDE VIEW)
N.T.S.

SECTION A-A (SIDE VIEW)
N.T.S.


SECTION A-A (SIDE VIEW)
N.T.S.

SECTION A-A (SIDE VIEW)
N.T.S.

SECTION A-A (SIDE VIEW)
N.T.S.

SECTION A-A (SIDE VIEW)
N.T.S.

NO	DESCRIPTION OF FIXTURE	DATE	BY
1	MAX SIZE 16" x 14"		
2	DESIGN LOADS +118.3 PSF -20.8 PSF		
3	TEST LOADS +27.5 PSF -3.3 PSF		



Amarr
CORPORATION

MODEL 6000 STANDARD w/Thursatic
Short Panel, Long Panel, and Fixed Panel

RC-6000-110-15
PAGE 1 OF 1



BUILDING CODE COMPLIANCE OFFICE
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1503
(305) 375-2901 FAX (305) 375-2908

PRODUCT CONTROL NOTICE OF ACCEPTANCE

Premdor Entry Systems
911 E. Jefferson, P.O. Box 76
Pittsburgh, KS 66762

CONTRACTOR LICENSING SECTION
(305) 375-2527 FAX (305) 375-2558

CONTRACTOR ENFORCEMENT DIVISION
(305) 375-2966 FAX (305) 375-2908

PRODUCT CONTROL DIVISION
(305) 375-2902 FAX (305) 372-6339

Your application for Notice of Acceptance (NOA) of:

Entergy 6-8 S/E Inswing Opaque Double w/sidelites Residential Insulated Steel Door
under Chapter 8 of the Code of Miami-Dade County governing the use of Alternate Materials and Types of Construction, and completely described herein, has been recommended for acceptance by the Miami-Dade County Building Code Compliance Office (BCCO) under the conditions specified herein.

This NOA shall not be valid after the expiration date stated below. BCCO reserves the right to secure this product or material at any time from a jobsite or manufacturer's plant for quality control testing. If this product or material fails to perform in the approved manner, BCCO may revoke, modify, or suspend the use of such product or material immediately. BCCO reserves the right to revoke this approval, if it is determined by BCCO that this product or material fails to meet the requirements of the South Florida Building Code.

The expense of such testing will be incurred by the manufacturer.

ACCEPTANCE NO.: 01-0314.23
EXPIRES: 04/02/2006

Raul Rodriguez
Chief Product Control Division

THIS IS THE COVERSHEET, SEE ADDITIONAL PAGES FOR SPECIFIC AND GENERAL
CONDITIONS
BUILDING CODE & PRODUCT REVIEW COMMITTEE

This application for Product Approval has been reviewed by the BCCO and approved by the Building Code and Product Review Committee to be used in Miami-Dade County, Florida under the conditions set forth above.

Francisco J. Quintana, R.A.
Director
Miami-Dade County
Building Code Compliance Office

APPROVED: 06/05/2001

Premdor Entry Systems

ACCEPTANCE No. 01-0314.23

APPROVED : JUN 05 2001

EXPIRES : April 02, 2006

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. SCOPE

- 1.1 This renews the Notice of Acceptance No. 00-0321.25 which was issued on April 28, 2000. It approves a residential insulated door, as described in Section 2 of this Notice of Acceptance, designed to comply with the South Florida Building Code (SFBC), 1994 Edition for Miami-Dade County, for the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the Design Pressure Rating values indicated in the approved drawings.

2. PRODUCT DESCRIPTION

- 2.1 The Series Entergy 6-8 S/E Inswing Opaque Double Residential Insulated Steel Doors with Sidelites-Impact Resistant Door Slab Only and its components shall be constructed in strict compliance with the following documents: Drawing No 31-1029-EM-I, Sheets 1 through 6 of 6, titled "Premdor (Entergy Brand) Double Door with Sidelites in Wood Frames with Bumper Threshold (Inswing)," prepared by manufacturer, dated 7/29/97 with revision C dated 01/11/00, bearing the Miami-Dade County Product Control approval stamp with the Notice of Acceptance number and approval date by the Miami-Dade County Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3. LIMITATIONS

- 3.1 This approval applies to single unit applications of pair of doors and single door only, as shown in approved drawings. Single door units shall include all components described in the active leaf of this approval.
- 3.2 Unit shall be installed only at locations protected by a canopy or overhang such that the angle between the edge of canopy or overhang to sill is less than 45 degrees. Unless unit is installed in non-habitable areas where the unit and the area are designed to accept water infiltration.

4. INSTALLATION


- 4.1 The residential insulated steel door and its components shall be installed in strict compliance with the approved drawings.
- 4.2 Hurricane protection system (shutters):
- 4.2.1 Door: the installation of this unit will not require a hurricane protection system.
- 4.2.2 Sidelite: the installation of this unit will require a hurricane protection system.

5. LABELING

- 5.1 Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS

- 6.1 Application for building permit shall be accompanied by copies of the following:
- 6.1.1 This Notice of Acceptance
- 6.1.2 Duplicate copies of the approved drawings, as identified in Section 2 of this Notice of Acceptance, clearly marked to show the components selected for the proposed installation.
- 6.1.3 Any other documents required by the Building Official or the South Florida Building Code (SFBC) in order to properly evaluate the installation of this system


Manuel Perez, P.E. Product Control Examiner
Product Control Division

Premdor Entry Systems

ACCEPTANCE No. 01-0314.23


APPROVED : JUN 05-2001


EXPIRES : April 02, 2006

NOTICE OF ACCEPTANCE: STANDARD CONDITIONS



1. Renewal of this Acceptance (approval) shall be considered after a renewal application has been filed and the original submitted documentation, including test supporting data, engineering documents, are no older than eight (8) years.
2. Any and all approved products shall be permanently labeled with the manufacturer's name, city, state, and the following statement: "Miami-Dade County Product Control Approved", or as specifically stated in the specific conditions of this Acceptance.
3. Renewals of Acceptance will not be considered if:
 - a. There has been a change in the South Florida Building Code affecting the evaluation of this product and the product is not in compliance with the code changes.
 - b. The product is no longer the same product (identical) as the one originally approved.
 - c. If the Acceptance holder has not complied with all the requirements of this acceptance, including the correct installation of the product.
 - d. The engineer who originally prepared, signed and sealed the required documentation initially submitted, is no longer practicing the engineering profession.
4. Any revision or change in the materials, use, and/or manufacture of the product or process shall automatically be cause for termination of this Acceptance, unless prior written approval has been requested (through the filing of a revision application with appropriate fee) and granted by this office.
5. Any of the following shall also be grounds for removal of this Acceptance:
 - a. Unsatisfactory performance of this product or process.
 - b. Misuse of this Acceptance as an endorsement of any product, for sales, advertising or any other purposes.
6. The Notice of Acceptance number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the Notice of Acceptance is displayed, then it shall be done in its entirety.
7. A copy of this Acceptance as well as approved drawings and other documents, where it applies, shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at all time. The engineer needs not reseal the copies.
8. Failure to comply with any section of this Acceptance shall be cause for termination and removal of Acceptance.
9. This Notice of Acceptance consists of pages 1, 2 and this last page 3.

END OF THIS ACCEPTANCE


Manuel Perez, P.E., Product Control Examiner
Product Control Division



OTHER CONFIGURATIONS




APPROVED AS CORRELATING WITH THE
SCOTT FLYNN BUILDING CODE
DATE: JUN 05 2001
BY: [Signature]
PROJECT: CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0314-23

C	BASE COUNTY MODIFICATIONS	DATE	BY
B	ADDED PAGE 5 (ORDER OPTIONS)	DATE	BY
A	ADDED SCREWS TO LITE FRAMES & EXTERIOR INSIDE CORNER CONFIGURATIONS	DATE	BY
A	ADDED OTHER CORNER CONFIGURATIONS	DATE	BY
A	ADDED OTHER CORNER CONFIGURATIONS	DATE	BY
A	ADDED OTHER CORNER CONFIGURATIONS	DATE	BY

31-1029-EM-1
SHEET 2 OF 6
REVISION C

MATERIALS LIST

ITEM NO.	DESCRIPTION	PART NUMBER	COMMENTS
1	WOOD HEAD JAMB	EM-14	1 1/4" X 4 9/16" MTL. TO BE PINE OR EQUIVALENT
2	COMPRESSION WEATHERSTRIP	EM-25	LOCKSCREEN BRAND LKXSEAL 9650- TEBRINZE
3	ALUMINUM ASTRAGAL	EM-12	PREMIOR BRAND OR EQUIVALENT - 5/8" ALUMINUM ASTRAGA
4	ALUMINUM-BUMPER THRESHOLD	EM-15	PREMIOR BRAND OR EQUIVALENT - 1 1/4" X 4 9/16"
5	TOP CHANNEL	EM-08	PREMIOR BRAND - 1 1/16" - 20 GA STEEL
6	STEEL SKIN	26 GA. C017 JMB -J00	100 MIL THICKNESS MIN. PER MIL. INDUSTRY PER DOOR, EXT. EXPOSED TO EXT.
7	POLYURETHANE FOAM CORE		BASF FOAM - DENSITY 2.0 TO 2.5 LBS./F.T. ³
8	BOTTOM CHANNEL	EM-07	PREMIOR BRAND - 1 1/16" - 20 GA STEEL
9	WOOD LOCK BLOCK	EM-09	4" X 9 1/2" MTL. TO BE PINE OR EQUIVALENT
10	STRIKE STILE	EM-06	PREMIOR BRAND - 1 1/16" - 20 GA STEEL
11	HINGE STILE	EM-05	PREMIOR BRAND - 1 1/16" - 20 GA STEEL
12	LOCK PREP FILLER PLATE	EM-10	PREMIOR BRAND - .050" THICK - MTL. TO BE POLYETHYLEN
13	4"x4" HINGE	EM-16	HAGER BRAND HINGE OR EQUIVALENT - .097 THICK (STEEL
14	WOOD HINGE JAMB	EM-13	1 1/4" X 4 9/16" MTL. TO BE PINE OR EQUIVALENT
15	#10-24 X 1/2" F.H.V.S.		(4) SCREWS PER HINGE INTO DOOR
16	#10 X 2" F.H.V.S.		(5) SCREWS THROUGH HINGE JAMB INTO SIDELITE JAMB, 8" DOWN FROM TO MAX 18" O.C. THEREAFTER (10) SCREWS THROUGH STRIKE JAMB INTO SIDELITE JAMB, 4" DOWN FROM TO MAX 8" O.C. THEREAFTER (20) SCREWS THROUGH EACH SIDELITE JAMB INTO SIDELITE, 4" DOWN FROM TOP, MAX 15" O.C. THEREAFTER
17	100 LBS. VARIOUM 1 1/2" CIRCUMF. OR 30% PER LACS VARIOUM 1 1/2" CIRCUMF.		REFER TO ELEVATION VIEW, FOR # OF SCREWS USED AND LOCATIONS
18	#10 X 3/4" F.H.V.S.		(2) SCREWS PER HINGE INTO JAMB
19	#8 X 2" F.H.V.S.		(2) SCREWS AT EACH STRIKE PLATE
20	LOCKSET		KWIKSET BRAND 200 LOCK OR HARLOC BRAND 100 LOCK
21	#10 X 1 3/4" F.H.V.S.		(2) SCREWS PER HINGE INTO JAMB
22	WOOD SIDELITE JAMB	EM-18	1 1/4" X 4 9/16" MTL. TO BE PINE OR EQUIVALENT
23	22" X 64" SINGLE PANEL GLASS	EM-19	TEMPERED GLASS IN POLYPROPYLENE FRAME - DE-1643 - C0DL - 1/8" CLEAR TEMPERED GLASS
24	SIDELITE TRIM (WOOD)	EM-20	5/16" X 1/2" MTL. TO BE PINE OR EQUIVALENT
25	WOOD CASING	EM-21	1 1/4" X 4 9/16" MTL. TO BE PINE OR EQUIVALENT - TIEMS ARE HOLDINGS USE FOR SIDE BY SIDE JAMBS AS MULLIONS
26	WOOD SIDELITE HEAD JAMB	EM-22	1 1/4" X 4 9/16" MTL. TO BE PINE OR EQUIVALENT
27	WOOD SIDELITE BASE	EM-23	1 1/4" X 4 9/16" MTL. TO BE PINE OR EQUIVALENT
28	POLYPROPYLENE LITE FRAME	DE-1643, C0DL-2	HP Polypropylene by C0DL
29	#6 X 1 1/2" PAN HEAD SCREWS		SCREWS SPACING TO BE 3" IN FROM EACH CORNER AND IN 18 PER FRAME TO EXCEED 14" BE THERE AFTER
30	SIDELITE STILES	EM-26	15/16" X 1 1/16" MTL. TO BE PINE OR EQUIVALENT
31	PIN NAIL		3/4" LONG NAIL, 4" IN FROM END, MAX 8" O.C. THEREAFTER, USED ON MULLIONS AND 10"




#995

DOW SILICONE

SECTION B-B

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE: JUN 05 2001
BY: [Signature]
PREMIOR ENTRY SYSTEMS
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0314-23

DATE COUNTY MODIFICATIONS		JULY 01	JD
A. ADDED PAGE 5 (COLOR OPTIONS)		10-1-99	RS
LIB	REVISIONS	DATE	BY
PROJECT NAME: ENTRY SYSTEMS		SCALE:	
DATE: 7-29-97		SCALE:	
PREMIOR ENTRY SYSTEMS			
911 E. JEFFERSON			
PITTSBURG, KS 66762			
31-1029-EM-1		SHEET 3 OF 6	
A		REVISION LETTER B	



PLEASE SEE 'GLAZING DETAIL'
DRAWING #31-1029-EM-1
SHEET 2 OF 6

SECTION C-C

APPROVED AS CORRELATING WITH THE
SPRINTLIP BUILDING CODE
DATE JUN 05 2005
BY Michael J. [Signature]
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-03.14.23

UNITS: UNLESS NOTED, FRAC. : DEC. : ANG. :
EXTENSIONS: UNLESS NOTED, STD. CON. UNITS.
ENGINEER:


DATE	COUNTY	MODIFICATIONS	DATE	BY
D				
C		MATERIAL WAS PDLYSTYRENE	6-2-99	RS
B		ADDED PAGE 5 CHAIR OPTIIONS	10-1-98	RS
A		ADD SCREWS TO LITE FRAME & MATERIAL LIST	12-18-97	R.S.
REV		REVISIONS	DATE	BY
DATE				

DR. BY R.S. DATE 7-29-97


PREMIER ENTRY SYSTEMS
31-1029-EM-1
SHEET 4 OF 6

REVISION LETTER D


OTHER DOOR CONFIGURATIONS




DXXD




DXX




DXXD




XX




DX



XD



DXXD




X

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE JUN 05 2009
BY *Signature*
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0314-23


LIMITS: UNLESS NOTED, F.O.C. : DEC : ANG :		ENGINEER:	
EXTRADUCE: UNLESS NOTED, STD. COM. 10.5		PART NAME:	
DATE: 1-11-01		SCALE:	
PREMIER ENTRY SYSTEMS		31-1029-EM-I	
911 E. JEFFERSON		SHEET 5 OF 6	
PHILADELPHIA, KS 66102		REVISION CENTER	

OTHER DOOR PANEL STYLES

79 5/16" MAX
36" MAX



BLANK TOP
4-PANEL



6-PANEL



4-PANEL



9-PANEL



10-PANEL



18-PANEL




8-PANEL



CROSSBUCK



12-PANEL



4-PANEL
EYEBROW



5-PANEL
W/SCROLL



5-PANEL
EYEBROW
W/SCROLL




5-PANEL



5-PANEL
EYEBROW

OTHER SIDELITE STYLES

79 3/16" MAX
36" MAX



SL-10



SL-20



SL-30



SL-60



SL-60



SL-69B



SL-69C



SL-25



SL-55



SL-300



SL-40



SL-90A



SL-90B



SL-90C




PD-1



PD-2



PD-3




PD-4



PD-5



PD-6



PD-7



PD-8



PD-9



PD-10



PD-11



PD-12



PD-13



PD-14



PD-15



PD-16



PD-17



PD-18




PD-19



PD-20



PD-21



PD-22



PD-23



PD-24



PD-25



PD-26



PD-27




PD-28



PD-29



PD-30



PD-31



PD-32




PD-33



PD-34



PD-35



PD-36



PD-37



PD-38



PD-39



PD-40



PD-41



PD-42



PD-43




PD-43A




PD-43B

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE JUN 05 2001
BY [Signature]
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLIANCE OFFICE
ACCEPTANCE NO. 01-0314.2.3


LIMITS: UNLESS NOTED, FRACTION : DECIMAL : ANGLES : EXTRUDINGS UNLESS NOTED, STD. COILS							
ENGINEER: _____				DATE: _____		BY: _____	
REV. NO. _____				DATE: _____		BY: _____	
PART NAME: PREMIUM DOOR				OPTIONS: _____		SCALE: _____	
DRAWN BY: JJJ				DATE: 12/15/01		SCALE: _____	
PREMIUM ENTRY SYSTEMS						31-1029-EM-1	
MIL C. JEFFERSON						SHEET 6 OF 6	
PITTSBURGH, KS 66762							




PD-438




PD-43A




PD-43




PD-42




PD-41




PD-40




PD-39




PD-38



PD-37



PD-36



PD-35

APPROVED AS COMPLYING WITH THE
SOUTH FLORIDA BUILDING CODE
DATE JUN 05 2001
BY Michael J. King
PRODUCT CONTROL DIVISION
BUILDING CODE COMPLAINTS OFFICE
ACCEPTANCE NO. 01-0314, 23

ATTACH STRIPAL THRU DOL
STRIKE PLATE TO THE HEDDER
AND NUTS WITH MINO X 1/4"
LATHING SCREWS

WOOD DOCKS BY OTHERS MUST BE ANCHORED
APPROPRIATELY TO TRANSFER LOADS TO THE STRUCTURE.
THE PRECEDING DRAWINGS ARE INTENDED TO
QUALIFY THE CONTRACTOR'S INSTALLATIONS.

SYSTEM IS ANCHORED TO A MINIMUM TWO BY WOOD
JACKETING.

1. MASONRY OR CONCRETE CONSTRUCTION WHERE
TRANSFERRAL WOOD BUCK.


2. MASONRY OR CONCRETE CONSTRUCTION WHERE
WOOD SYSTEM IS ANCHORED DIRECTLY TO CONCRETE
OR MASONRY WITH NO WITHOUT A NON-STRUCTURAL
LAY BY WOOD BUCK.

MINIMUM ANCHORING SCREWS TO BE MINO WITH
9/16" PH TAPCONS WITH 1 1/2".

NTO MASONRY.

UNIT MUST BE INSTALLED WITH MIAMI-DADE COUNT
APPROVED SHUITERS

THREE STAPLES PER SIDE JAMB INTO HEADER ON S
NO DOOR, THREE STAPLES PER JAMB INTO THRESHOLD
INDICES AND DOOR



PREMDOR (CENTERGY BRAND) DOUBLE DOOR
WITH SIDELITES IN WOOD FRAMES
WITH BUMPER THRESHOLD (INSWING)