



---

**Britt Surveying and Mapping, LLC**  
1438 SW Main Blvd • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

---

02/09/2023

Permit # 000045348

L-29049

Re: 02032-213

Whiddon Construction

To Whom It May Concern:

The finished slab elevation is found to be 108.09 feet. The minimum floor elevation per the building permit is shown to be 110 feet (plat is in NGVD 29 datum or 109.13 feet NAVD 88). All elevations are shown in NAVD 88 datum except as stated.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a faint circular seal. The seal contains the text "STATE OF FLORIDA" and "SURVEYOR" around the perimeter, with "L. SCOTT BRITT" in the center.

L. Scott Britt  
LS 5757