

March 27, 2020

Trademark Construction Group
163 SW Midtown Place, Ste 101
Lake City, FL 32025

Subject: Permit # 39442 - Lot 40, Country Lake in Woodborough, Phase 2

Dear Matt:

Daniel & Gore, LLC has performed a vertical survey on Lot 40, Country Lake in Woodborough, Phase 2, Columbia County, Florida from a benchmark being a FDOT concrete monument (2918010 BM4) on the Easterly right of way of I-75 (elevation – 138.98', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 140.0'.
- The top of the stem walls of the residence is at 140.9', being 0.9' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

