

---

**Britt Surveying and Mapping, LLC**  
1438 SW Main Blvd • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

04/27/2023

L-29455

Permit # 000045027


Re: Lots 21 Southern Meadows Phase 3

Melanie & Kevin Walstrom

To Whom It May Concern:

The finished floor elevation on Lot 21 is found to be 89.59 feet. The Plat of record shows a Minimum floor elevation of 85.5 feet. The floor elevation shown hereon is in NAVD 88 datum.

Sincerely,



L. Scott Britt  
LS 5757