Ward Job Hunter Redge to Randy



1730 NW Oakland Ave Lake City, FL 32055 George Anderson Owner
Quality Pre-Engineered Wood Trusses

Bus (386) 752-3103 Fax (386) 961-8290

October 9, 2006

Columbia County Building Department Lake City, Florida 32055

To Whom It May Concern,

The trusses on the SLK Construction Ward job A-2 will work with moving the bearing in the truss  $1 \frac{1}{2}$ ". The D-2 will work with a  $1 \frac{3}{4}$ " bearing under the truss leg.

If you have any questions, please feel free to contact me at 386.752.3103.

Thank you,

Shawn Anderson

Sha / Cente

# 24533