

3 7405



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

11/25/18

L-25549

Re: Lot 7 Amelia Landings Phase 1

Bradley Franks Construction

To Whom It May Concern:

The elevation of the stem wall is found to be 115.06 feet. The lowest adjacent grade is 111.9 feet and the highest adjacent grade is 113.0 feet. The centerline of SW Beacon Way is determined to be 114.96 feet. The elevations shown hereon are based on plat datum.

Sincerely,


L. Scott Britt
LS 5757