
COMM: 2K1239

SHEET:

3 0 32

AR0007005





MEZZANINE ELECTRICAL PLAN SCALE: 3/16" = 1'-0"

Electrical SYMBOLS

POWER

- P DUPLEX WALL RECEPTACLE
- DUPLEX WALL RECPT., BELOW COUNTER
- P 240V OUTLET
- PGFI GND FAULT INTERRUPTER DUPLEX RECEPT.
- PGF WEATHER PROOF GFI DUPLEX RECEPT.
- ELECTRICAL PANEL ELECTRICAL PANEL
 - ØEF. EXHAUST FAN
- SMOKE DETECTOR, 120V
- NON-FUSED DISC. SWITCH
- NON-FUSED WEATHER-PROOF DISC. SWITCH
- JUNCTION BOX

LIGHTING

- SPST WALL SWITCH
- DPDT WALL SWITCH (3-WAY)
- DIMMER WALL SWITCH (600 W)
- INC. CHANDELIER, 600W
- 2 LAMP FLU. PRISMATIC WRAP SURFACE FIXTURE

 - INC. LIGHT FIXTURE 60 W INC. O HIGH HAT DOWN LIGHT - 75W INC.
 - HIGH HAT EYEBALL 500W QUARTZ
 - SWITCH/FIXTURE WIRING
 - CONTROL WIRE / LOW YOLTAGE
 - TIME CLOCK
 - EXIT LIGHT W/ BAT. PACK, GREEN LETTERS ON WHITE FACE
 - OLO DUAL HEAD EMERGENCY LIGHT W/ BAT. PACK
- CEILING FAN W/ LIGHT KIT



TO TICI

NOTE! EMERGENCY LIGHTING AND EXIT SIGNS, SHALL BE PROVIDED AS DIRECTED BY THE FIRE MARSHAL, AND SHALL BE WIRED PER NEC 700-12F.

TYPE W/ RATINGS & LOADS.

ELECTRICAL CONT'R SHALL PREPARE "AS-BUILT" SHOP DUGS INDICATING ALL ELECTRICAL WORK, INCLUDING ANY CHANGES TO THE ELEC. PLAN, ADD'NS TO THE ELEC. PLAN, RISER DIAGRAM, AS-BUILT PANEL SCHEDULE W/ ALL CKTS IDENTIFIED W/ CKT Nr., DESCRIPTION & BRKR, SERVICE ENT. & ALL UNDERGROUND WIRE LOCATIONS/ROUTING/DEPTH.

RISER DIA, SHALL INCLUDE WIRE SIZES/TYPE & EQUIPMENT

CONTRACTOR SHALL PROVIDE I COPY OF AS-BUILT DWGS

TO OWNER & I COPY TO THE PERMIT ISSUING AUTHORITY.

0 0

d) gridb