

Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025 386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

09/12/18

L-25393

Re: Lot 9 West Paces

Trent Giebeig

To Whom It May Concern:

The top of the foundation is determined to be 97.65 feet on said lot 9. The adjacent lowest grade is determined to be 93.6 feet and the highest adjacent grade is 95.8 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerali

L. Scott Britt LS 5757