J-12046 - C-1309 Job: Date: Jun 24, 2025 LaNiika Stewart

# **Project Information**

Phelps Construction Lake City, FL For:

Notes:

# **Design Information**

Weather: Gainesville, FL, US

## **Winter Design Conditions**

## **Summer Design Conditions**

Outside db Inside db	33 °F 70 °F	Outside db Inside db	92 °F 75 °F
Design TD	37 °F	Design TD Daily range	17 °F M
Ventilation Method	ASHRAE 62.2-2019	Relative humidity Moisture difference	50 % 43 gr/lb

#### **Heating Summary**

## **Sensible Cooling Equipment Load Sizing**

**Cooling Equipment Summary** 

Structure	40864	Btuh	Structure	31517	Btuh
Ducts (R-6.0)	5027	Btuh	Ducts (R-6.0)	3714	
Central vent (180 cfm)	7234	Btuh	Central vent (180 cfm)	3430	Btuh
Outside air			Outside air		
Humidification	0	Btuh	Blower	0	Btuh
Piping Equipment load	0	Btuh			
Equipment load	53126	Btuh	Use manufacturer's data	n	ı
			Rate/swing multiplier	0.97	
Infiltration	on		Equipment sensible load	37656	Btuh

Method Construction quality		Simplified Average	Latent Cooling Equipme	Latent Cooling Equipment Load Sizin		
Fireplaces		Average 0	Structure	6904	Btuh	
			Ducts	2148	Btuh	
			Central vent (180 cfm)	5297	Btuh	
	Heating	Cooling	Outside air			
Area (ft²)	2500	2500	Equipment latent load	14349	Btuh	
Volume (ft³)	52290	52290				
Air changes/hour	0.32	0.16	Equipment Total Load (Sen+Lat)	52005	Btuh	
Equiv. AVF (cfm)	279	139	Req. total capacity at 0.80 SHR	3.9	ton	

## **Heating Equipment Summary**

Make	Rheem		Make	Rheem
Trade	554443466446544		Trade	DD4.443/004.10314
Model	RP14AY60AJ2NA		Cond	RP14AY60AJ2NA
AHRI ref	214803216		Coil	RH2TY6024STANNJ
Efficiency		7 0 HCDE2	AHRI ref	214803216

		AHRI ref 214803216	
Efficiency	7.8 HSPF2	Efficiency 11.7 E	ER2,15.2 SEER2
Heating input		Sensible cooling	45600 Btuh
Heating output	55000 Btuh @ 47°F	Latent cooling	11400 Btuh
Temperature rise	26 °F	Total cooling	57000 Btuh
Actual air flow	1900 cfm	Actual air flow	1900 cfm
Air flow factor	0.041 cfm/Btuh	Air flow factor	0.054 cfm/Btuh
Static pressure	0.53 in H2O	Static pressure	0.53 in H2O
Space thermostat		Load sensible heat ratio	0.73
Capacity balance point = 0 °F			
Б. І			

Input = 15 kW, Output = 51808 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Job: J-12046 - C-1309 Date: Jun 24, 2025 LaNiika Stewart

# **Project Information**

Phelps Construction For: Lake City, FL

# **Cooling Equipment**

## **Design Conditions**

Outdoor design DB: 92.4°F Sensible gain: Btuh Entering coil DB: 38661 77.2°F Entering coil WB: Outdoor design WB: 75.8°F Latent gain: 14349 Btuh 64.4°F Indoor design DB: 75.0°F Total gain: 53010 Btuh

Estimated airflow: Indoor RH: 50% 1900 cfm

#### Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Rheem Model: RP14AY60AJ2NA+RH2TY6024STANNJ

Actual airflow: 1900 cfm

118% of load Sensible capacity: 45600 Btuh 79% of load Latent capacity: 11400 Btuh

Total capacity: 57000 108% of load SHR: 80% Btuh

## **Heating Equipment**

#### **Design Conditions**

Outdoor design DB: 33.3°F Heat loss: 53126 Btuh Entering coil DB: 66.0°F

Indoor design DB: 70.0°F

## Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Rheem Model: RP14AY60AJ2NA+RH2TY6024STANNJ

Actual airflow: 1900 cfm

Output capacity: 55000 Btuh 104% of load Capacity balance: 0°F Economic balance: 0 °F Supplemental heat required: 0 Btuh

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 1900 cfm

15.2 0 °F Output capacity: kW 98% of load Temp. rise:

Meets all requirements of ACCA Manual S.