

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

July 30, 2022

Bryan Zecher

Bryan Zecher Construction

386.752.8653

bczecher@comcast.net

re: ELEVATION LETTER – 1276 SW JASMINE STREET, FORT WHITE, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. The foundation of the home was complete. Photo 1 shows the foundation looking south and Photo 2 show the driveway looking north. The topography of the site drains to the south. The home will be located in zone X. The attached flood report shows no wetlands or flood zones on the property.



Photo 1



Photo 2

Based on the LIDAR on the Columbia County website, the existing road centerline elevation varies from 100.6' +/- to 97.6' +/- and the existing ground at the building site is 96.8' +/- . The minimum finished floor of the home shall be **98.10'**. The finished floor of the home will be below the required elevation of one foot above the adjacent road.

CAROL CHADWICK, P.E.

Page 2

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A0141
0D0000017EB6D92
4CE0005954C,
cn=Carol Chadwick
Date: 2022.07.30
11:01:56 -04'00'

Carol Chadwick, P.E.

attachment: SRWMD Flood Report, site plan by others