



#35948

Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/01/18

L-25449

Re: Lot 5 Laurel Lakes Phase 3

Housecraft Homes

To Whom It May Concern:

The finished floor elevation of Lot 5 is found to be 154.11 feet. The lowest adjacent grade is determined to be 150.5 feet and the highest adjacent grade is found to be 153.8 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757