

To: All Concerned Parties**Project No.**
21-0536.06**From:** Austin Blazs**Date:** January 31, 2023**RE:** Foundation Elevation & Setback Certification Letter for Lot 6, Forest Country 6th Addition

Please accept this memorandum as my certification that the foundation constructed on Lot 6, Forest Country 6th Addition, as per plat recorded in Plat Book 9, Pages 66-67, Public Records of Columbia County, FL are in compliance with the Zoning setback requirements. In addition, the elevation of the foundations of the residence currently under construction on said Lot 6, was field measured on January 31, 2023 to be **100.82** feet. The benchmark used as a basis for this measurement is based on The North American Vertical Datum of 1988 and was derived National Geodetic Survey Monument "STEINRIED AZIMUTH" (P.I.D. BD1035).

The minimum finished floor elevation, per Elevation Letter – 285 SW Pinehurst Drive, Lake City provided by Carol Chadwick, P.E., for Lot 6 is **97.40** feet.

Austin Blazs

Digitally signed by Austin Blazs
DN: E=austinb@chw-inc.com,
CN=Austin Blazs, O="Causseaux,
Hewett, & Walpole, Inc.",
L=Alachua, S=Florida, C=US
Date: 2023.02.01 16:04:17 -05'00'

Austin Blazs, PSM

Registered Florida Surveyor and Mapper Certificate Number 7401

