

43302

**D**  
**G** **Daniel & Gore, LLC**  
**Professional Surveying and Mapping**

P.O. Box 1501  
Lake City, Florida 32056

**May 2, 2022**

Aaron Simque Homes  
333 SW Rosemary Drive  
Lake City, FL 32025

**Subject: Lot 147, Preserve at Laurel Lake, Unit 1**

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 147, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 114.5'.
- The elevation of the concrete foundation is at 116.2', being 1.7' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM



---

Scott Daniel, PSM • Cell: (386) 208-4176 • E-mail: [sdaniel@dgsurveying.com](mailto:sdaniel@dgsurveying.com)

David Gore • Cell: (386) 365-0298 • E-mail: [dgore@dgsurveying.com](mailto:dgore@dgsurveying.com)

Fax: (904) 339-9229