



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM
CONSTRUCTION INSPECTION AND FINAL APPROVAL

APPLICATION #: AP1807310
PERMIT #: 12-SC-2472853
DOCUMENT #: F11791868
DATE PAID: 03/01/2022
FEE PAID: 310.00
RECEIPT #: 12-PID-5465646

APPLICANT: RICHARD**22-0174 STEWART

AGENT: Ronald Ford (Ford's Septic)

PROPERTY ADDRESS: 22388 N US HWY 441 White Springs, FL 32096

LOT:

BLOCK:

SUBDIVISION:

ID#: 01515-000

CHECKED [X] ITEMS ARE NOT IN COMPLIANCE WITH STATUTE OR RULE AND MUST BE CORRECTED.

TANK INSTALLATION

[] [01] TANK SIZE [1] 900 [2] 300
[] [02] TANK MATERIAL Pre CC / Pre CC
[] [03] OUTLET DEVICE T / f
[] [04] MULTI-CHAMBERED [] (N)
[] [05] OUTLET FILTER Pol / lock TCS
[] [06] LEGEND 1. 3410709DL32.3410703SC3
[] [07] WATERTIGHT -
[] [08] LEVEL -
[] [09] DEPTH TO LID -

DRAINFIELD INSTALLATION

[] [10] AREA [1] 575 [2] SQFT
[] [11] DISTRIBUTION BOX HEADER X
[] [12] NUMBER OF DRAINLINES 1. 4 2.
[] [13] DRAINLINE SEPARATION (7, 6, 6, 6)
[] [14] DRAINLINE SLOPE
[] [15] DEPTH OF COVER
[] [16] ELEVATION [] ABOVE / BELOW BM 12
[] [17] SYSTEM LOCATION
[] [18] DOSING PUMPS
[] [19] AGGREGATE SIZE
[] [20] AGGREGATE EXCESSIVE FINES
[] [21] AGGREGATE DEPTH

FILL / EXCAVATION MATERIAL

[] [22] FILL AMOUNT
[] [23] FILL TEXTURE
[] [24] EXCAVATION DEPTH
[] [25] AREA REPLACED
[] [26] REPLACEMENT MATERIAL

SETBACKS

[] [27] SURFACE WATER FT
[] [28] DITCHES FT
[] [29] PRIVATE WELLS 115' FT
[] [30] PUBLIC WELLS FT
[] [31] IRRIGATION WELLS FT
[] [32] POTABLE WATER 30' FT
[] [33] BUILDING FOUNDATIONS 100' FT
[] [34] PROPERTY LINES FT
[] [35] OTHER FT

FILLED / MOUND SYSTEM

[] [36] DRAINFIELD COVER
[] [37] SHOULDERS
[] [38] SLOPES 5/27/22
[] [39] STABILIZATION

ADDITIONAL INFORMATION

[] [40] UNOBSTRUCTED AREA
[] [41] STORMWATER RUNOFF
[] [42] ALARMS ESI
[] [43] MAINTENANCE AGREEMENT
[] [44] BUILDING AREA
[] [45] LOCATION CONFORMS WITH SITE PLAN
[] [46] FINAL SITE GRADING
[] [47] CONTRACTOR Jareds 5/27/22
[] [48] OTHER INF ARC 24

ABANDONMENT

[] [49] TANK PUMPED
[] [50] TANK CRUSHED & FILLED

Comments:

CONSTRUCTION [] APPROVED / DISAPPROVED [] CHD DATE: 5/27/22
FINAL SYSTEM [] APPROVED / DISAPPROVED [] CHD DATE: 5/27/22

(Explanation of Violations on following page)

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC