



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/30/2021

L-27399

Permit #000041371

Re: Lot 18 Block C Wise Estates

Trent Giebeig Construction

To Whom It May Concern:

The top of the finished slab elevation on this parcel is 93.36 feet. The elevation required per the building permit is shown to be 93.2 feet. The elevations shown hereon are based on NGVD 29 datum.

Sincerely,

L. Scott Britt
LS 5757

