




August 2, 2022

Ref: Hardees sites – ODMB footing detail

279 W Duval Street



To Whom it May Concern,

It has come to our attention that some of the details on the structural sheets were incorrect. Please accept our apologies for the mishap as they have now been corrected.

Items that have been updated. Foundation section, Typical anchor bolt pattern and base plate detail. The rod was changed to be galv. Threaded and the washers have been updated to fit the base plate.

Should you have any questions please feel free to call me or send me an email.

Once again, we apologize for the inconvenience.

Sincerely,

Jason C. Wilson

Principal

Retail / Commercial

Direct: 757.213.6348 | **Cell:** 757.513-5262

1317 Executive Boulevard, Suite 200 | Chesapeake, Virginia 23320

jwilson@rmm.com | www.rmm.com

