



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/12/2020 Revised

Permit # 000040550

Lot 10 of Haight-Ashbury

L-26965

Cornerstone Development

To whom it may concern,

The elevation of the top of the slab on Lot 10 is found to be 119.02 feet. The minimum floor elevation is shown to be 119.00 feet per the permit. The elevations Shown Hereon are based on NAVD 88 Datum.

Sincerely,

*Original
Sealed*

L. Scott Britt
LS 5757