DALE TOMPKINS RESIDE... Job:

Date: Aug 13, 2021 By: Plan: J-6838

Project Information

For:

Tompkins Addition 257 SW Hudson In, Lake City, FL 32025

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Summer Design Conditions

Outside db Inside db	33 °F 70 °F	Outside db Inside db	92 °F 75 °F
Design TD	37 °F	Design TD Daily range	17 °F M
		Relative humidity Moisture difference	50 % 44 gr/lb

Heating Summary

Sensible Cooling Equipment Load Sizing

Structure	20007	Btuh	Structure	22364 Btuh
Ducts	3660	Btuh	Ducts	5075 Btuh
Central vent (0 cfm)	0	Btuh	Central vent (0 cfm)	0 Btuh
(none)			(none)	
Humidification	0	Btuh	Blower	0 Btuh
Piping Equipment load	0	Btuh		
Equipment load	23666	Btuh	Use manufacturer's data	У
			Rate/swing multiplier	1.00
In	ıfiltration		Equipment sensible load	27439 Btuh

Method	Simplified
Construction quality Fireplaces	Average 0
i iiopiaooo	•

Latent Cooling Equipment Load Sizing

2356 Btuh

Портасов		Ü	Ducts Central vent (0 cfm)	1045 0	
Area (ft²) Volume (ft³)	Heating 1491 11928	Cooling 1491 11928	(none) Equipment latent load	3400	Btuh
Air changes/hour Equiv. AVF (cfm)	0.45 89	0.23 46	Equipment Total Load (Sen+Lat) Req. total capacity at 0.80 SHR	30840 2.9	

Structure

Heating Equipment Summary

Input = 7 kW, Output = 23168 Btuh, 100 AFUE

Cooling Equipment Summary

Make Trade Model AHRI ref	Trane TRANE 4TWR6036H1 7562981			Make Trade Cond Coil AHRI ref	Trane TRANE 4TWR6036H TEM6A0C36 7562981			
Efficiency Heating input Heating outp Temperature Actual air flo Air flow facto Static presso Space therm Capacity bal	out e rise w or ure	33000 26 1160 0.049	°F	Efficiency Sensible cod Latent cooling Total cooling Actual air flo Air flow facto Static pressi Load sensib	oling ng J w or ure	13.0 EER, 1	27840 6960 34800 1160 0.042	Btuh Btuh Btuh
Doolare								

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Job: DALE TOMPKINS RESIDE...

Date: Aug 13, 2021

By: **LCF** Plan: J-6838

Project Information

For: **Tompkins Addition**

257 SW Hudson In, Lake City, FL 32025

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	27439	Btuh	Entering coil DB:	77.0°F
Outdoor design WB:	75.8°F	Latent gain:	3400	Btuh	Entering coil WB:	63.5°F
Indoor design DB:	75.0°F	Total gain:	30840	Btuh	-	
Indoor RH:	50%	Estimated airflow:	1160	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Trane Model: 4TWR6036H1+TEM6A0C36H31++TDR

Actual airflow: 1160 cfm

101% of load Sensible capacity: 27840 Btuh Latent capacity: 6960 Btuh 205% of load

Total capacity: 34800 113% of load SHR: 80% Btuh

Heating Equipment

Design Conditions

Outdoor design DB: 33.2°F Heat loss: 23666 Btuh Entering coil DB: 69.0°F

Indoor design DB: 70.0°F

Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Trane Model: 4TWR6036H1+TEM6A0C36H31++TDR

Actual airflow: 1160 cfm

Output capacity: 33000 Btuh 139% of load Capacity balance: 25 °F Economic balance: Supplemental heat required: 0 Btuh -99 °F

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 1160 cfm

50 °F Output capacity: 6.8 kW 98% of load Temp. rise:

Meets all requirements of ACCA Manual S.