



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

05/20/2022

Permit # 000043013

L-28614

Ingrid Geiger

Re: 05842-002

To Whom It May Concern:

There are 3 new slabs on this parcel. The top of the finished slab on the Northwest side is found to be 188.76 feet. The top of the finished slab on the Northeast side is found to be 188.76. The finished slab on the South side is found to be 189.20 feet. Engineering plans show the two north floor elevations to be 189.0 feet and the southerly slab to be 189.4 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt

LS 5757