

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen
Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

October 21, 2025

Ralph Cruz
210.305.9208
nicepeggy2020@gmail.com

re: ELEVATION LETTER – 163 SW RIDDLE LANE, LAKE CITY, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. Per the map by SRWMD, there are no wetlands or floodplains on the site. Refer to the attached site plan by others. The topography of the site drains to the north.

The finished floor elevation of the home shall be 12" above the adjacent ground for the entire perimeter of the foundation, except driveways and sidewalks which must be flush with the finished floor elevation. The finished floor of the home will be below required elevation of one foot above the adjacent road.

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,


Carol Chadwick, P.E.

attachments: SRWMD map & site plan sketch


This item has been digitally signed and sealed by Carol Chadwick, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

CC Job #FL25541





CRUX



Parcel No: 04-4S-16-02772-053

Owner: CRUZ RAPHAEL, CRUZ PEGAH

Subdivision:

Lot:

Acres: 0.9402014

Deed Acres: 1.03 Ac

District: District 3 Robbie Hollingsworth

Future Land Uses: Residential - Low

Flood Zones:

Official Zoning Atlas: RR

Scanned North
10/14/25