

# Columbia County Building Department Culvert Permit

36406

Culvert Permit No.  
000002557

DATE 03/05/2018 PARCEL ID # 24-4S-16-03113-169

APPLICANT BRENDA RAPP PHONE 386.752.5152

ADDRESS 1482 SW COMMERCIAL GLN LAKE CITY FL 32025

OWNER STANLEY CRAWFORD CONSTRUCTION, INC. PHONE 386.752.5152

ADDRESS 203 SW PLATEAU GLEN LAKE CITY FL 32024

CONTRACTOR W. STANLEY CRAWFORD PHONE 386.752.5152

LOCATION OF PROPERTY 47-S TO C-242, TR TO WISE, TR TO GARDNER, TL TO PLATEAU, TR  
AND ITS 2ND FROM END OF CUL-DE-SAC ON L.

SUBDIVISION/LOT/BLOCK/PHASE/UNIT WISE ESTATES 39 C

## INSTALLATION INFORMATION

SIGNATURE

Brenda Rapp

- (A) A culvert shall be required to be installed as part of any newly constructed private driveway or road, or public road, which connects to a county road in Columbia County. Culvert installation for residential use shall require a permit issued by the Building and Zoning Department. Prior to any culvert permit being issued, an inspection by the Public Works Department shall be required to determine the proper size, length, and location for installation. Culvert installation for commercial, industrial, and other uses shall conform to the approved site plan or to the specifications of a registered engineer. Joint use culverts will comply with Florida Department of Transportation specifications.
- (B) The culvert shall comply and be installed in accordance with Columbia County Land Development Regulation, Access Control, Section 4.2.3 standards. Proper installation of the culvert shall be verified by a final inspection performed by the Public Works Department.
- (C) All culverts required by this policy shall be installed prior to the Building Department granting permission to connect permanent electrical service to the facility or facilities being serviced by newly constructed private driveway or road. In cases where no electrical service exists, installation shall be completed prior to final inspection approval.
- (D) Mitered-end culverts shall be used in the following applications:  
(1) When the culvert is to be placed giving access to a paved street.; (2) When the road is contained within a subdivision (recorded or unrecorded) that has not reached a "build out" of fifty percent (50%) or more.; (3) In all new subdivisions for residential use. New subdivisions shall be required as part of the final plat to specify culvert diameter and length.; (4) When the predominant use already established by the use of mitered-end culverts period.

☐

Culvert installation shall conform to the approved site plan standards.

☐

Department of Transportation Permit installation approved standards.

☒

Shall conform to Public Works Determinations as Stated Below:

INSTALL MIN 32' X 18" CORR METAL CULVERT, W/ CONCRETE MITERED  
END, W/ 6" X 6" WELDED WIRE REBAR OR CULVERT BOLTS.P W Inspectors Name: DAVID M. MCCORMICKDate: 3/9/18

Final Inspection Date: \_\_\_\_\_

P W Inspectors Name: \_\_\_\_\_

Signature: \_\_\_\_\_

## CONTACT FOR REQUIREMENTS AND INSPECTIONS:

PUBLIC WORKS DEPARTMENT Phone: 386-758-1019

Amount Paid 25.00

## SCHEDULE INSPECTIONS ONLINE

Check No. 8468[www.columbiacountyfla.com/PermitSearch/InspectionCalendar.aspx](http://www.columbiacountyfla.com/PermitSearch/InspectionCalendar.aspx)

All Proper Safety Requirements Should Be Followed During The Installation Of The Culvert